# JLS



## PRODUCT DESCRIPTION

The Dimension CP-Series are cost optimized power supplies without compromising quality, reliability and performance. The most outstanding features of the CP10.242-R2 unit is the high efficiency, electronic inrush current limitation, active PFC, wide operational temperature range and the extraordinary small size. The units include a decoupling MOSFET for building 1+1 or N+1 redundant power supply systems. The devices also offer PowerBoost: Power reserves of 20%, which may even be used continuously at temperatures up to +45°C.

These redundancy power supplies come with three connection terminal options; screw terminals, springclamp terminals or plug connector terminals which allows replacement on an active application.

The CP10.242-R2 features an enhanced DC input voltage range.

High immunity to transients and power surges as well as low electromagnetic emission, a DC-OK relay contact and a large international approval package for a variety of applications makes this unit suitable for nearly every situation.

#### **ORDER NUMBERS**

Description: Order Number: CP10.242-R2 Power supply CP10.242-R2-xx

Accessories: ZM10.WALL ZM12.SIDE

Wall/panel mount bracket Side mount bracket

# REDUNDANCY POWER 1AC 24V 240W SUPPLY

- AC 100-240V Wide-range input
- Width only 39mm
- Built-in decoupling MOSFET for 1+1 and N+1 redundancy
- Efficiency up to 94.7%
- 20% Output power reserves (PowerBoost)
- Safe Hiccup<sup>PLUS</sup> overload mode
- Easy fuse breaking 3 times nominal current for 12ms
- Active power factor correction (PFC)
- Minimal inrush current surge
- Full power between -25°C and +60°C
- DC-OK relay contact
- Current sharing feature included
- 3 Year warranty

### SHORT-FORM DATA

Output voltage	DC 24V	0%/+6%			
	Factory setting 2	4.1V			
Output current	10A	Up to +60°C ambient			
	7.5A	At +70°C ambient			
	Derate linearly b	etween +60°C and +70°			
PowerBoost	12A	Up to +45°C ambient			
		Linear decrease to nominal power between +45°C and +60°C			
Input voltage AC	AC 100-240V	-15% / +10%			
Mains frequency	50-60Hz	±6%			
Input current AC	2.17 / 1.14A	At 120 / 230Vac			
Power factor	0.99 / 0.97	At 120 / 230Vac			
Input voltage DC	DC 110-300V	±20%			
Input current DC	2.35 / 0.84A	At 110 / 300Vdc			
AC Inrush current	6 / 9A <sub>peak</sub>	At 120 / 230Vac			
Efficiency	93 / 94.7%	At 120 / 230Vac			
Power losses	18.1 / 13.4W	At 120 / 230Vac			
Hold-up time	37 / 37ms	At 120 / 230Vac			
Temperature range	e -25°C to +70°C				
Size (w x h x d) Weight	39x124x117mm 600g	Without DIN rail			

#### MAIN APPROVALS

For details and the complete approval list, see chapter 21.



UL 61010-2-201

All parameters are specified at 24V, 10A, 230Vac, 25°C ambient and after a 5 minutes run-in time unless otherwise noted.

Aug. 2022 / Rev. 1.0 DS-CP10.242-Rx-xx-en

# **PULS**

#### Index

1	Intended Use	4
2	Installation Instructions	4
3	AC-Input	5
4	DC-Input	6
5	Input Inrush Current	7
6	Output	8
7	Hold-up Time	9
8	DC-OK Relay Contact	10
9	Efficiency and Power Losses	11
10	Lifetime Expectancy	12
11	MTBF	12
12	Functional Diagram	13
13	Terminals And Wiring	13
14	Replacing units while the system is running	14
15	Front Side And User Elements	15
16	EMC	16
17	Environment	17
18	Protection Features	18
19	Safety Features	18

Dielec	tric Strength	19					
Approved, Fulfilled or Tested Standards							
Regula	atory Product Compliance	21					
Physic	al Dimensions And Weight	22					
Access	ories	23					
24.1	ZM10.Wall - Wall/Panel Mount Bracket	23					
24.2	ZM12.Side - Side Mounting Bracket	24					
Applic	ation Notes	25					
25.1	Peak Current Capability	25					
25.2	Adjusting the output voltage	26					
25.3	Output Circuit Breakers	27					
25.4	Parallel Use to Increase Output Power	28					
25.5	Parallel Use for Redundancy	29					
25.6	Series Operation	30					
25.7	Charging of Batteries	30					
25.8	Two Phase Operation	30					
25.9	Use in a Tightly Sealed Enclosure	31					
25.10	Mounting Orientations	32					
	Appro Regula Physic 24.1 24.2 Applic 25.1 25.2 25.3 25.4 25.5 25.6 25.7 25.8 25.9	Regulatory Product CompliancePhysical Dimensions And WeightAccessories					

The information given in this document is correct to the best of our knowledge and experience at the time of publication. If not expressly agreed otherwise, this information does not represent a warranty in the legal sense of the word. As the state of our knowledge and experience is constantly changing, the information in this data sheet is subject to revision. We therefore kindly ask you to always use the latest issue of this document (available under www.pulspower.com).

No part of this document may be reproduced or utilized in any form without our prior permission in writing.

Packaging and packaging aids can and should always be recycled. The product itself may not be disposed of as domestic refuse.



## TERMINOLOGY AND ABBREVIATIONS

PE and 🕀 Symbol	PE is the abbreviation for <b>P</b> rotective <b>E</b> arth and has the same meaning as the symbol $\oplus$ .
Earth, Ground	This document uses the term "earth" which is the same as the U.S. term "ground".
t.b.d.	To be defined, value or description will follow later.
AC 230V	A figure displayed with the AC or DC before the value represents a nominal voltage with standard tolerances (usually ±15%) included.
	E.g.: DC 12V describes a 12V battery disregarding whether it is full (13.7V) or flat (10V)
230Vac	A figure with the unit (Vac) at the end is a momentary figure without any additional tolerances included.
50Hz vs. 60Hz	As long as not otherwise stated, AC 230V parameters are valid at 50Hz mains frequency.
may	A key word indicating flexibility of choice with no implied preference.
shall	A key word indicating a mandatory requirement.
should	A key word indicating flexibility of choice with a strongly preferred implementation.
1+1 Redundancy	Use of two identical power supplies in parallel to provide continued operation following most failures in a single power supply. The two power supply outputs should be isolated from each other by utilizing diodes or other switching arrangements. E.g. two 10A power supplies are
	needed to achieve a 10A redundant system.
N+1 Redundancy	Use of three or more identical power supplies in parallel to provide continued operation following most failures in a single power supply. All power supply outputs should be isolated from each other by utilizing diodes or other switching arrangements. E.g.: To achieve a 40A redundant system, five 10A power supplies are needed in a N+1 redundant system.



Fig. 1: N+1 Redundancy



Fig. 2: 1+1 Redundancy



#### 1. Intended Use

This device is designed for installation in an enclosure and is intended for commercial use, such as in industrial control, process control, monitoring, measurement, Audio/Video, information or communication equipment or the like.

Do not use this device in equipment, where malfunctioning may cause severe personal injury or threaten human life without additional appropriate safety devices, that are suited for the application. If this device is used in a manner outside of its specification, the protection provided by the device may be impaired.

#### 2. Installation Instructions

#### **A** WARNING Risk of electrical shock, fire, personal injury or death.

- Turn power off before working on the device. Protect against inadvertent re-powering.
- Do not open, modify or repair the device.
- Use caution to prevent any foreign objects from entering the housing.
- Do not use in wet locations or in areas where moisture or condensation can be expected.
- Do not touch during power-on, and immediately after power-off. Hot surfaces may cause burns.

This device may only be installed and put into operation by qualified personnel. This device does not contain serviceable parts. The tripping of an internal fuse is caused by an internal defect. If damage or malfunction should occur during installation or operation, immediately turn power off and send the device to the factory for inspection.

Install the device in an enclosure providing protection against electrical, mechanical and fire hazards. Install the device onto a DIN rail according to EN 60715 with the input terminals on the bottom of the device. Other mounting orientations require a reduction in output current.

Make sure that the wiring is correct by following all local and national codes. Use appropriate copper cables that are designed for a minimum operating temperature of 60°C for ambient temperatures up to +45°C, \*75°C for ambient temperatures up to +60°C and \*90°C for ambient temperatures up to +70°C. Ensure that all strands of a stranded wire enter the terminal connection. Unused screw terminals should be securely tightened.

Unused screw terminals should be securely tightened:

The device is designed for pollution degree 2 areas in controlled environments. No condensation or frost is allowed.

The enclosure of the device provides a degree of protection of IP20. The enclosure does not provide protection against spilled liquids. The isolation of the device is designed to withstand impulse voltages of overvoltage category III according to IEC 60664-1.

The device is designed as "Class of Protection I" equipment according to IEC 61140. Do not use without a proper PE (Protective Earth) connection. The device is suitable to be supplied from TN, TT or IT mains networks. The continuous voltage between the input terminal and the PE potential must not exceed 300Vac.

The input can also be powered from batteries or similar DC sources. The continuous voltage between the supply voltage and the PE/ground potential must not exceed 375Vdc. A disconnecting means shall be provided for the input of the device.

The device is designed for convection cooling and does not require an external fan. Do not obstruct airflow and do not cover ventilation grid! The device is designed for altitudes up to 5000m. Above 2000m a reduction in output current and over voltage category is required. Keep the following minimum installation clearances: 40mm on top, 20mm on the bottom, 5mm left and right side. Increase the 5mm to 15mm in case the adjacent device is a heat source. When the device is permanently loaded with less than 50%, the 5mm can be reduced to zero.

The device is designed, tested and approved for branch circuits up to 32A (IEC) and 30A (UL) and without additional protection device. If an external fuse is utilized, do not use circuit breakers smaller than 6A B- or C-Characteristic to avoid a nuisance tripping of the circuit breaker. The maximum surrounding air temperature is +70°C. The operational temperature is the same as the ambient or surrounding air temperature and is defined 2cm below the device. The device is designed to operate in areas between 5% and 95% relative humidity. Do not unplug the connectors more often than 20 times in total.

## 3. AC-Input

The device is suitable to be supplied from TN-, TT- or IT-mains networks with AC voltage. For suitable DC supply voltages see chapter 4.

AC input	nom.	AC 100-240V	,			
AC input range		85-264Vac				
		264-300Vac	Occasio	nally for maxii	mal 500ms	
Allowed voltage L or N to earth	max.	300Vac	Continu	Continuous, according to IEC 60664-1		
Input frequency	nom.	50-60Hz	±6%			
Turn-on voltage	typ.	80Vac	Steady-	state value, se	e Fig. 3-1	
Shut-down voltage	typ.	70Vac	Steady-	state value, se	e Fig. 3-1	
	typ.	55Vac	Dynami	c value for ma	x. 250ms	
External input protection	See rec	ommendations	in chapter 2	•		
		AC 100V	AC 120V	AC 230V		
Input current	typ.	2.63A	2.17A	1.14A	At 24V, 10A, see Fig. 3-3	
Power factor *)	typ.	0.99	0.99	0.97	At 24V, 10A, see Fig. 3-4	
Crest factor **)	typ.	1.5	1.5	1.65	At 24V, 10A	
Start-up delay	typ.	300ms	290ms	240ms	See Fig. 3-2	
Rise time	typ.	30ms	30ms	30ms	At 24V, 10A const. current load,	
					0mF load capacitance, see Fig. 3-2	
	typ.	75ms	75ms	75ms	At 24V, 10A const. current load,	
					20mF load capacitance, see Fig. 3-2	
Turn-on overshoot	max.	200mV	200mV	200mV	See Fig. 3-2	

\*) The power factor is the ratio of the true (or real) power to the apparent power in an AC circuit.

\*\*) The crest factor is the mathematical ratio of the peak value to RMS value of the input current waveform.



Fig. 3-1: Input voltage range



Fig. 3-3: Input current vs. output current at 24V output voltage



Fig. 3-2: Turn-on behavior, definitions



Fig. 3-4: Power factor vs. output current at 24V output voltage

## 4. DC-Input

DC input	nom.	DC 110-300V	±20%
DC input range		88-360Vdc	
DC input current	typ.	2.35A	At 110Vdc, 24V, 10A
	typ.	0.84A	At 300Vdc, 24V, 10A
Allowed voltage (+) or (–) input to earth	max.	360Vdc	Continuous, according to IEC 60664-1
Turn-on voltage	typ.	80Vdc	Steady state value
Shut-down voltage	typ.	70Vdc	Steady state value
	typ.	55Vdc	Dynamic value for max. 250ms



Fig. 4-1: Wiring for DC Input

The device is suitable to be supplied from a DC input voltage.

#### Instructions for DC use:

a) Use a battery or a similar DC source.

#### WARNING

A supply from the intermediate DC-bus of a frequency converter is not recommended and can cause a malfunction or damage the unit.

- b) Connect (+) pole to L and (–) pole to N.
- c) Connect the PE terminal to an earth wire or to the machine ground.

# 5. Input Inrush Current

An active inrush limitation circuit (NTCs, which are bypassed by a relay contact) limits the input inrush current after turnon of the input voltage.

The charging current into EMI suppression capacitors is disregarded in the first microseconds after switch-on.



Fig. 5-1: Typical turn-on behaviour at nominal load and 25°C ambient

Fig. 5-2: Typical turn-on behaviour at nominal load, 230Vac input and 25°C ambient

#### 6. Output

The output provides a SELV/PELV/ES1 rated voltage, which is galvanically isolated from the input voltage. The output of the devices includes a decoupling MOSFET for building 1+1 or N+1 redundant power supply systems.

The device is designed to supply any kind of loads, including capacitive and inductive loads. If extreme large capacitors, such as EDLCs (electric double layer capacitors or "UltraCaps") with a capacitance larger than 1.5F are connected to the output, the unit might charge the capacitor in the Hiccup<sup>PLUS</sup> mode.

The device is featured with a "soft output regulation characteristic" in order to achieve current share between multiple devices when they are connected in parallel. The "soft output regulation characteristic" regulates the output voltage in such a manner that the voltage at no load is approx. 4% higher than at nominal load.

Output voltage	nom.	DC 24V	23.8-25.2V		
Adjustment range		See chapter 2	5.2		
Factory settings	typ.	24.1V	$\pm 0.2\%$ , at 10A, cold unit (results to typ. 23.9V $^{\pm 0.2\%}$ at 12A and typ. 25.1V $^{\pm 0.2\%}$ at no load)		
Line regulation	max.	10mV	Between 85Vac and 300Vac		
Load regulation	max.	1000mV	Between 0A and 10A, static value, see Fig. 6-1		
Ripple and noise voltage	max.	50mVpp	Bandwidth 20Hz to 20MHz, 50Ohm		
Output current	nom.	10A	At 24V and up to +60°C ambient temperatures, see Fig. 17-1		
	nom.	7.5A	At 24V and +70°C ambient temperature, see Fig. 17-1		
	Derate l	inearly between +	⊦60°C and +70°C, see chapter 17		
PowerBoost <sup>1)</sup>	no	m. 12A	At 24V and up to +45°C ambient temperature, see Fig. 17-1		
	PowerBo	oost decreases lin	early to nominal power between +45°C and +60°C, see chapter 17		
Fuse breaking current <sup>2)</sup>	typ.	30A	Up to 12ms once every five seconds, see Fig. 6-2.		
Overload behavior	Continuous current		For output voltage above 13Vdc, see Fig. 6-1		
	Intermit	tent current <sup>3)</sup>	For output voltage below 13Vdc, see Fig. 6-1		
Overload/	max.	15.5A	Continuous current, see Fig. 6-1		
short-circuit current	typ.	14A	Intermitted current peak value for typ. 2s		
			Load impedance 10mOhm, see Fig. 6-2.		
			Discharge current of output capacitors is not included.		
	max.	5A	Intermitted current average value (R.M.S.)		
Output conscitors		4.400	Load impedance 10mOhm, see Fig. 6-2		
Output capacitance	typ.	4 400µF	Included inside the power supply		
Back-feeding loads	max.	35V	The unit is resistant and does not show malfunctioning when a load feeds back voltage to the power supply. It does not matter whether the power supply is on or off. The absorbing energy can be calculated according to the built-in large sized output capacitor.		

#### 1) PowerBoost

This power/current is continuously allowed up to an ambient temperature of +45°C.

Above +45°C, do not use this power/current longer than a duty cycle of 10% and/or not longer than 1 minute every 10 minutes.

2) The fuse breaking current is an enhanced transient current which helps to start heavy loads or to trip fuses on faulty output branches. The output voltage stays above 20V.

3) At heavy overloads (when output voltage falls below 13V), the power supply delivers continuous output current for 2s. After this, the output is switched off for approx. 18s before a new start attempt is automatically performed. This cycle is repeated as long as the overload exists. If the overload has been cleared, the device will operate normally. See Fig. 6-3.

CP10.242-R2





Fig. 6-1: Output voltage vs. output current, typ.



Fig. 6-3: Short-circuit on output, Hiccup<sup>PLUS</sup> mode, typ.

### 7. Hold-up Time



Fig. 6-2: Dynamic overcurrent capability, typ.

		AC 100V	AC 120V	AC 230V	
Hold-up time	typ.	73ms	73ms	73ms	At 24V, 5A, see Fig. 7-1
	min.	55ms	55ms	55ms	At 24V, 5A, see Fig. 7-1
	typ.	37ms	37ms	37ms	At 24V, 10A, see Fig. 7-1
	min.	28ms	28ms	28ms	At 24V, 10A, see Fig. 7-1



Fig. 7-1: Hold-up time vs. input voltage



Fig. 7-2: Shut-down behaviour, definitions

## 8. DC-OK Relay Contact

This feature monitors the output voltage on the output terminals of a running power supply.

Contact closes	As soon as the output voltage reaches typ. 90% of the adjusted output voltage level.
Contact opens	As soon as the output voltage dips more than 10% below the adjusted output voltage. Short dips will be extended to a signal length of 100ms. Dips shorter than 1ms will be ignored.
Switching hysteresis	typ. 1V
Contact ratings	Maximal 60Vdc 0.3A, 30Vdc 1A, 30Vac 0.5A, resistive load Minimal permissible load: 1mA at 5Vdc
Isolation voltage	See dielectric strength table in chapter 20.



Fig. 8-1: DC-ok relay contact behavior

## 9. Efficiency and Power Losses

		AC 100V	AC 120V	AC 230V	
Efficiency	typ.	92.2%	93%	94.7%	At 24V, 10A
	typ.	91.9%	92.8%	94.6%	At 24V, 12A (PowerBoost)
Average efficiency*)	typ.	91.8%	92.4%	93.9%	25% at 2.5A, 25% at 5A, 25% at 7.5A, 25% at 10A
Power losses	typ.	4W	3.7W	2.9W	At 24V, 0A
	typ.	11.3W	10.7W	8.6W	At 24V, 5A
	typ.	20.3W	18.1W	13.4W	At 24V, 10A
	typ.	25.4W	22.3W	16.4W	At 24V, 12A (PowerBoost)

\*)

The average efficiency is an assumption for a typical application where the power supply is loaded with 25% of the nominal load for 25% of the time, 50% of the nominal load for another 25% of the time, 75% of the nominal load for another 25% of the time and with 100% of the nominal load for the rest of the time.



Fig. 9-1: Efficiency vs. output current at 24V, typ.



Fig. 9-3: Efficiency vs. input voltage at 24V, 10A, typ.



Fig. 9-2: Losses vs. output current at 24V, typ.



Fig. 9-4: Losses vs. input voltage at 24V, 10A, typ.



#### 10. Lifetime Expectancy

The Lifetime expectancy shown in the table indicates the minimum operating hours (service life) and is determined by the lifetime expectancy of the built-in electrolytic capacitors. Lifetime expectancy is specified in operational hours and is calculated according to the capacitor's manufacturer specification. The manufacturer of the electrolytic capacitors only guarantees a maximum life of up to 15 years (131 400h). Any number exceeding this value is a calculated theoretical lifetime, which can be used to compare devices.

	AC 100V	AC 120V	AC 230V	
Lifetime expectancy	143 000h	153 000h	188 000h	At 24V, 5A and 40°C
	405 000h	434 000h	531 000h	At 24V, 5A and 25°C
	66 000h	78 000h	109 000h	At 24V, 10A and 40°C
	188 000h	220 000h	307 000h	At 24V, 10A and 25°C
	37 000h	47 000h	71 000h	At 24V, 12A and 40°C
	105 000h	132 000h	200 000h	At 24V, 12A and 25°C

#### 11. MTBF

MTBF stands for Mean Time Between Failure, which is calculated according to statistical device failures, and indicates reliability of a device. It is the statistical representation of the likelihood of a unit to fail and does not necessarily represent the life of a product.

The MTBF figure is a statistical representation of the likelihood of a device to fail. A MTBF figure of e.g. 1 000 000h means that statistically one unit will fail every 100 hours if 10 000 units are installed in the field. However, it can not be determined if the failed unit has been running for 50 000h or only for 100h.

For these types of units the MTTF (Mean Time To Failure) value is the same value as the MTBF value.

	AC 100V	AC 120V	AC 230V	
MTBF SN 29500, IEC 61709	535 000h	556 000h	641 000h	At 24V, 10A and 40°C
	972 000h	1 006 000h	1 138 000h	At 24V, 10A and 25°C
MTBF MIL HDBK 217F	205 000h	208 000h	232 000h	At 24V, 10A and 40°C; Ground Benign GB40
	279 000h	283 000h	318 000h	At 24V, 10A and 25°C; Ground Benign GB25
	45 000h	46 000h	53 000h	At 24V, 10A and 40°C; Ground Fixed GF40
	58 000h	59 000h	63 000h	At 24V, 10A and 25°C; Ground Fixed GF25

## 12. Functional Diagram



Fig. 12-1: Functional diagram

### 13. Terminals And Wiring

The terminals are IP20 Finger safe constructed and suitable for field- and factory wiring.

	Input	Output	DC-OK-Signal
Туре	Plug connector with screw terminals	Plug connector with screw terminals	Plug connector with screw terminals
Solid wire	max. 4mm <sup>2</sup>	max. 4mm <sup>2</sup>	max. 1.5mm <sup>2</sup>
Stranded wire	max. 2.5mm <sup>2</sup>	max. 2.5mm <sup>2</sup>	max. 1.5mm <sup>2</sup>
American Wire Gauge	AWG 20-12	AWG 20-12	AWG 26-16
Max. wire diameter (including ferrules)	2.4mm	2.4mm	1.8mm
Recommende tightening torque	max. 0.5Nm	max. 0.5Nm	max. 0.8Nm
Wire stripping length	7mm	7mm	6mm
Screwdriver	3.5mm slotted or cross- head No 2	3.5mm slotted or cross- head No 2	3mm slotted
	Do not unplug the connectors more often than 20 times in total	Do not unplug the connectors more often than 20 times in total	Do not unplug the connectors more often than 20 times in total

#### Instructions for Wirings:

a) Use appropriate copper cables that are designed for minimum operating temperatures of:

+60°C for ambient up to +45°C and

+75°C for ambient up to +60°C minimum

+90°C for ambient up to +70°C minimum.

- b) Follow national installation codes and installation regulations!
- c) Ensure that all strands of a stranded wire enter the terminal connection!
- d) Unused terminal compartments should be securely tightened.
- e) Ferrules are allowed.

# PULS

## 14. Replacing units while the system is running

This feature is available only for the units, which are equipped with hot-swappable plug connectors.



Fig. 14-1: Replacing the power supply while the system is running

#### Instructions:

- a) Switch-off circuit breaker (1a).
- b) Remove plug (2a).
- c) Remove plug (3a). The plug prevents the cables from shorting.
- d) Change power supply.
- e) Put the plug (3a) back in.
- f) Put the plug (2a) back in.
- g) Turn-on the circuit breaker (1a).
- h) The circuit is redundant again.

To replace the right power supply, repeat the process above using (1b), (2b) and (3b).

### 15. Front Side And User Elements



#### 16. EMC

The EMC behavior of the device is designed for applications in industrial environment as well as in residential, commercial and light industry environments.

EMC Immunity	According to generic standards: EN 61000-6-1 and EN 61000-6-2				
Electrostatic discharge	EN 61000-4-2	Contact discharge	8kV	Criterion A	
		Air discharge	15kV	Criterion A	
Electromagnetic RF field	EN 61000-4-3	80MHz - 2.7GHz	20V/m	Criterion A	
Fast transients (Burst)	EN 61000-4-4	Input lines	4kV	Criterion A	
		Output lines	2kV	Criterion A	
		DC-OK signal (coupling clamp)	2kV	Criterion A	
Surge voltage on input	EN 61000-4-5	$L \rightarrow N$	2kV	Criterion A	
		$L\toPE,N\toPE$	4kV	Criterion A	
Surge voltage on output	EN 61000-4-5	$(+) \rightarrow (-)$	1kV	Criterion A	
		(+) / (−) → PE	2kV	Criterion A	
Surge voltage on DC-OK	EN 61000-4-5	DC-OK signal $\rightarrow$ PE	1kV	Criterion A	
Conducted disturbance	EN 61000-4-6	0.15 - 80MHz	20V	Criterion A	
Mains voltage dips	EN 61000-4-11	0% of 100Vac	0Vac, 20ms	Criterion A	
		40% of 100Vac	40Vac, 200ms	Criterion C	
		70% of 100Vac	70Vac, 500ms	Criterion A	
		0% of 200Vac	0Vac, 20ms	Criterion A	
		40% of 200Vac	80Vac, 200ms	Criterion A	
		70% of 200Vac	140Vac, 500ms	Criterion A	
Voltage interruptions	EN 61000-4-11	0% of 200Vac (=0V)	5000ms	Criterion C	
Voltage sags	SEMI F47	Dips on the input voltage according to SEMI F47 standard			
		80% of 120Vac (96Vac)	1000ms	Criterion A	
		70% of 120Vac (84Vac)	500ms	Criterion A	
		50% of 120Vac (60Vac)	200ms	Criterion A	
Powerful transients	VDE 0160	Over entire load range	750V, 0.3ms	Criterion A	

#### Performance criterions:

A: The device shows normal operation behavior within the defined limits.

C: Temporary loss of function is possible. The device may shut-down and restarts by itself. No damage or hazards for the device will occur.

5 5	N 61000-6-3 and EN 61000-6-4
EN 55011, EN 55015, EN 55032, FCC Part 15, CISPR 11, CISPR 32	Class B
IEC/CISPR 16-1-2, IEC/CISPR 16-2-1	Limits for DC power ports according to EN 61000-6-3 are fulfilled
EN 55011, EN 55032	Class B
EN 61000-3-2	Class A fulfilled between 0A and 12A load Class C fulfilled between 6A and 12A load
EN 61000-3-3	Fulfilled
	FCC Part 15, CISPR 11, CISPR 32 IEC/CISPR 16-1-2, IEC/CISPR 16-2-1 EN 55011, EN 55032 EN 61000-3-2

This device complies with FCC Part 15 rules.

Operation is subjected to following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

#### Switching Frequencies

PFC converter	100kHz	Fixed frequency
Main converter	84-140	Output load dependent
Auxiliary converter	60kHz	Fixed frequency

#### 17. Environment

Operational temperature	-25°C to +70°C	The operational temperature is the same as the ambient or surrounding temperature. It is defined as the air temperature 2cm below the device.		
Storage temperature	-40°C to +85°C	For storage and transportation		
Output derating	0.25A/K	Between +60°C and +70°C		
	0.63A/1000m or 5K/1000m	For altitudes >2000m, see Fig. 17-2		
	0.38A/-5kPa or 3K/-5kPa	For atmospheric pressures <80kPA, see Fig. 17-2		
	The derating is not hardware controlled below the derated current limits in orde	l. The user has to take care by himself to stay er not to overload the unit.		
Humidity	5 to 95% r.h.	According to IEC 60068-2-30 Do not energize while condensation is present.		
Atmospheric pressure	110-47kPa	See Fig. 17-2 for details		
Altitude	Up to 5000m	See Fig. 17-2 for details		
Over-voltage category	III	According to IEC 60664-1 for altitudes <2000m		
	II	According to IEC 60664-1 for altitudes >2000m and 5000m and atmospheric pressures from 80-47kPa		
Degree of pollution	2	According to IEC 60664-1, not conductive		
Vibration sinusoidal	2-17.8Hz: ±1.6mm;	According to IEC 60068-2-6		
	17.8-500Hz: 2g			
	2 hours / axis			
Shock	30g 6ms, 20g 11ms	According to IEC 60068-2-27		
	3 bumps per direction, 18 bumps in total			
	Shock and vibration is tested in combina 15mm and a thickness of 1.3mm and sta	ation with DIN rails EN 60715 with a height of Indard orientation.		
Audible noise	Some audible noise may be emitted from the power supply during no load, overload or short circuit.			







Fig. 17-2: Output current vs. altitude

### 18. Protection Features

Output over-voltage protection	typ. 30.5Vdc	The output shuts down and automatically attempts to restart for three times. If after the third time the restart
	max. 32Vdc	still fails, the output is switched off permanently until the line input is disconnected for a second.
Degree of protection	IP 20	EN/IEC 60529
Penetration protection	>4mm	E.g. screws, small parts
Over-temperature protection	Included	Output shut-down with automatic restart. Temperature sensors are installed on critical components inside the unit and turn the unit off in safety critical situations, which can happen e.g. when ambient temperature is too high, ventilation is obstructed or the derating requirements are not followed. There is no correlation between the operating temperature and turn- off temperature since this is dependent on input voltage, load and installation methods.
Input transient protection	MOV (Metal Oxide Varistor)	For protection values see chapter (EMC).
Internal input fuse	Included	Not user replaceable slow-blow high-braking capacity fuse

## 19. Safety Features

Class of protection	I	According to IEC 61140	
Isolation resistance	>500MOhm	At delivered condition between input and output, measured with 500Vdc	
	>500MOhm	At delivered condition between input and PE, measured with 500Vdc	
	>500MOhm	At delivered condition between output and PE, measured with 500Vdc	
	>500MOhm	At delivered condition between output and DC-OK contacts, measured with 500Vdc	
PE resistance	<0.10hm	Resistance between PE terminal and the housing in the area of the DIN rail mounting bracket.	
Touch current (leakage current)	typ. 0.14mA / 0.36mA	At 100Vac, 50Hz, TN-, TT-mains / IT-mains	
	typ. 0.2mA / 0.5mA	At 120Vac, 60Hz, TN-, TT-mains / IT-mains	
	typ. 0.33mA / 0.86mA	At 230Vac, 50Hz, TN-, TT-mains / IT-mains	
	max. 0.18mA / 0.43mA	At 110Vac, 50Hz, TN-, TT-mains / IT-mains	
	max. 0.26mA / 0.61mA	At 132Vac, 60Hz, TN-, TT-mains / IT-mains	
	max. 0.44mA / 1.05mA	At 264Vac, 50Hz, TN-, TT-mains / IT-mains	

# 7015

## 20. Dielectric Strength

The output voltage is floating and has no ohmic connection to the ground.

Type and routine tests are conducted by the manufacturer. Field tests may be conducted in the field using the appropriate test equipment which applies the voltage with a slow ramp (2s up and 2s down). Connect all input-terminals together as well as all output poles before conducting the test. When testing, set the cut-off current settings to the value in the table below.

It is recommend that either the (+) pole, the (-) pole shall be connected to the protective earth system. This helps to avoid situations in which a load starts unexpectedly or can not be switched off when unnoticed earth faults occur.



		А	В	С	D
Type test	60s	2500Vac	4000Vac	1000Vac	500Vac
Factory test	5s	2500Vac	2500Vac	500Vac	500Vac
Field test	5s	2000Vac	2000Vac	500Vac	500Vac
Field test cut-off current settings		>10mA	>10mA	>20mA	>1mA

Fig. 20-1: Dielectric strength

B<sup>\*)</sup> When testing input to DC-OK ensure that the max. voltage between DC-OK and the output is not exceeded (column D). We recommend connecting DC-OK pins and the output pins together when performing the test.



# 21. Approved, Fulfilled or Tested Standards

IEC 60950	CB Report	CB Scheme Certificate IEC 60950-1 - General safety requirements for Information Technology Equipment (ITE)
IEC 62368	CB Report	CB Scheme Certificate IEC 62368-1 - Audio/video, information and communication technology equipment - Safety requirements Output safety level: ES1
IEC 61010	CB Report	CB Scheme Certificate IEC 61010-2-201 - Electrical Equipment for Measurement, Control and Laboratory Use - Particular requirements for control equipment
UL 61010	CUL US LISTED	UL Certificate Listed equipment for category NMTR - UL 61010-2-201 - Electrical equipment for measurement, control and laboratory use - Particular requirements for control equipment Applicable for US and Canada E-File: E198865
Semi F47	SEMI F47	Test Report Voltage Sag Immunity for Semiconductor Processing Equipment Tested for AC 208V L-L or L-N mains voltages, nominal output voltage and nominal output load
IEC 60068-2-60	Corrosion IEC 60068-2-60 Method 4	Manufacturer's Declaration (Online Document) Environmental Tests, Flowing Mixed Gas Corrosion Test Test: Ke - Method 4 H2S: 10ppb NO2: 200ppb Cl2: 10ppb SO2: 200ppb Test Duration: 3 weeks, which simulates a service life of at least 10 years.
ISA-71.04-1985	Corrosion G3-ISA-71.04	Manufacturer's Declaration (Online Document) Airborne Contaminants Corrosion Test Severity Level: G3 Harsh H2S: 100ppb NOx: 1250ppb Cl2: 20ppb SO2: 300ppb Test Duration: 3 weeks, which simulates a service life of at least 10 years
VDMA 24364	LABS VDMA 24364-C1-L/W	Paint Wetting Impairment Substances Test (or LABS-Test) Tested for Zone 2 and Test Class C1 according to VDMA 24364-C1-L/W for solvents and water-based paints



# 22. Regulatory Product Compliance

EU Declaration of		The CE mark indicates conformance with the European
Conformity	CE	<ul> <li>EMC directive</li> <li>Low-voltage directive (LVD)</li> <li>RoHS directive</li> </ul>
WEEE Regulation	X	Manufacturer's Declaration EU Directive on Waste Electrical and Electronic Equipment Registered in Germany as business to business (B2B) products. EU Directive 2012/19/EU
REACH Regulation	REACH 🗸	Manufacturer's Declaration EU Regulation regarding the Registration, Evaluation, Authorization and Restriction of Chemicals EU Regulation 1907/2006
RoHS-China	25	Manufacturer's Statement Administrative Measures for the Restriction of the Use of Hazardous Substances in Electrical and Electronic Products 25 years

# 23. Physical Dimensions And Weight

Width	39mm		
Height	124mm		
Depth	117mm		
	The DIN rail depth must be added to the unit depth to calculate the total required installation depth.		
Weight	600g		
DIN rail	Use 35mm DIN rails according to EN 60715 or EN 50022 with a height of 7.5 or 15mm.		
Housing material	Body: Aluminium alloy Cover: Zinc-plated steel		
Installation clearances	See chapter 2.		
Penetration protection	Small parts like screws, nuts, etc. with a diameter larger than 4mm		



All dimensions in mm unless otherwise noted.

### 24. Accessories

#### 24.1. ZM10.WALL - WALL/PANEL MOUNT BRACKET

This bracket is used to mount the devices on a wall/panel without utilizing the DIN rail. The bracket can be mounted without detaching the DIN rail brackets from the power supply.



Fig. 24-1: Isometric view



Fig. 24-4: Wall/panel mounting, front view



Fig. 24-2: Isometric view



Fig. 24-5: Hole pattern for wall mounting

All dimensions in mm unless otherwise noted.



Fig. 24-3: Isometric view



Fig. 24-6: Wall/panel mounting, side view

45

39

CP10

Power

Supply

135 124

Fig. 24-9: Mounting dimensions

side mounting bracket

104

ġ.

CP10

Power

Supply

ιc

43



#### 24.2. ZM12.SIDE - SIDE MOUNTING BRACKET

This bracket is used to mount the power supply sideways with or without utilizing a DIN rail. The two aluminum brackets and the black plastic slider of the unit have to be detached, so that the steel brackets can be mounted. For sideway DIN rail mounting, the removed aluminum brackets and the black plastic slider need to be mounted on the steel bracket.



Fig. 24-7: Side mounting with DIN rail brackets



Fig. 24-8: Side mounting without DIN rail brackets



## 25. Application Notes

#### 25.1. PEAK CURRENT CAPABILITY

The device can deliver peak currents (up to several milliseconds) which are higher than the specified short term currents.

This helps to start current demanding loads. Solenoids, contactors and pneumatic modules often have a steady state coil and a pick-up coil. The inrush current demand of the pick-up coil is several times higher than the steady-state current and usually exceeds the nominal output current. The same situation applies when starting a capacitive load.

The peak current capability also ensures the safe operation of subsequent circuit breakers of load circuits. The load branches are often individually protected with circuit breakers or fuses. In case of a short or an overload in one branch circuit, the fuse or circuit breaker need a certain amount of over-current to open in a timely manner. This avoids voltage loss in adjacent circuits.

The extra current (peak current) is supplied by the power converter and the built-in large sized output capacitors of the power supply. The capacitors get discharged during such an event, which causes a voltage dip on the output. The following examples show typical voltage dips for resistive loads:



#### 25.2. ADJUSTING THE OUTPUT VOLTAGE

A voltage adjustment potentiometer can be found behind the flap on the front of the unit (see chapter). However, it is not recommended to change the output voltage since load sharing between power supplies connected in parallel can only be achieved by a precise setting of the output voltages. The factory settings allow precise load sharing and only qualified personnel should change the adjustment potentiometer.

Lower end of the spec	ified adjustme	nt range	
Output voltage	nom.	24V	Due to the soft output voltage regulation characteristic (parallel mode feature) a setting to 24V results to an output voltage of 23.8V <sup>±0.2%</sup> at 12A and 25.0V <sup>±0.2%</sup> at no load. See Fig. 25-4.
Output current	min.	12A	At +45°C
	min.	10A	At +60°C
	min.	7.5A	At +70°C
		Reduce output cu	irrent linearly between +45°C and +70°C
Upper end of the spec	ified adjustmer	nt range	
Output voltage	nom.	27V	Due to the soft output voltage regulation characteristic (parallel mode feature) a setting to 27V results to an output voltage of 26.7V <sup>±0.2%</sup> at 10.6A and 28.2V <sup>±0.2%</sup> at no load. See Fig. 25-4.
Output current	min.	10.6A	At +45°C
	min.	8.9A	At +60°C
	min.	6.7A	At +70°C
		Reduce output cu	irrent linearly between +45°C and +70°C

The maximum output voltage which can occur at the clockwise end position of the potentiometer due to tolerances is 30V. It is not a guaranteed value which can be achieved.

Current values between 24 and 27V can be interpolated.



Fig. 25-4: Adjustment range of the output voltage

The output voltage shall only be changed when absolutely necessary, e.g. for battery charging as described in the next chapter.

### 25.3. OUTPUT CIRCUIT BREAKERS

Standard miniature circuit breakers (MCB's or UL 1077 circuit breakers) are commonly used for AC-supply systems and may also be used on 24V branches.

MCB's are designed to protect wires and circuits. If the ampere value and the characteristics of the MCB are adapted to the wire size that is used, the wiring is considered as thermally safe regardless of whether the MCB opens or not.

To avoid voltage dips and under-voltage situations in adjacent 24V branches which are supplied by the same source, a fast (magnetic) tripping of the MCB is desired. A quick shutdown within 10ms is necessary corresponding roughly to the ride-through time of PLC's. This requires power supplies with high current reserves and large output capacitors. Furthermore, the impedance of the faulty branch must be sufficiently small in order for the current to actually flow. The best current reserve in the power supply does not help if Ohm's law does not permit current flow. The following table has typical test results showing which B- and C-Characteristic MCBs magnetically trip depending on the wire cross section and wire length.



Maximal wire length \*) for a fast (magnetic) tripping:

	0.75mm <sup>2</sup>	1.0mm <sup>2</sup>	1.5mm <sup>2</sup>	2.5mm <sup>2</sup>
C-2A	30m	37m	54m	84m
C-3A	25m	30m	46m	69m
C-4A	9m	15m	25m	34m
C-6A	3m	3m	4m	7m
C-8A	-	-	-	-
B-6A	12m	15m	21m	34m
B-10A	3m	3m	4m	9m
B-13A	2m	2m	3m	6m

\*) Don't forget to consider twice the distance to the load (or cable length) when calculating the total wire length (+ and - wire).



#### 25.4. PARALLEL USE TO INCREASE OUTPUT POWER

Power supplies can be paralleled to increase the output power. For redundancy applications one extra power supply is always needed for sufficient output current in case one unit fails.

The unit is permanently set to "parallel use" mode in order to achieve load sharing between devices connected in parallel. The "Parallel use" mode regulates the output voltage in such a manner that the voltage at no load is approx. 4% higher than at nominal load. See also chapter 6.

Energize all units at the same time. It also might be necessary to cycle the input power (turn-off for at least five seconds), if the output was in overload or short circuits and the required output current is higher than the current of one unit.

Keep an installation clearance of 15mm (left / right) between two devices and avoid installing devices on top of each other. Do not use devices in parallel in mounting orientations other than the standard mounting orientation or in any other condition where a reduction of the output current is required (e.g. altitude).

Pay attention that leakage current, EMI, inrush current will increase when using multiple devices.



Fig. 25-6: Output current vs. ambient temp. for two paralleled units







24V, 20A



#### 25.5. PARALLEL USE FOR REDUNDANCY

Power supplies can be paralleled for redundancy to gain higher system availability. The unit is already equipped with a MOSFET as decoupling device on the output to avoid, that a faulty unit becomes a load for the other devices and the output voltage cannot be maintained anymore.

#### **Recommendations for building redundant power systems:**

- a) Use separate input fuses for each power supply.
- b) Monitor the individual power supply units by utilizing the built-in DC-OK relay contacts on each power supply.



Failure Monitor Loac Output 24V 10A Output 24V 10A Output 24V 10A 圡 木 木 DC-OK Ø DC-OK Ø DC-OK 😣 DC-\₽ DC-(冒 CP10.241-Rx Power Supply CP10.241-Rx Power Supply CP10.241-Rx Power Supply Input L N PE Input L N PE Input L N PE T Т

Fig. 25-8: Wiring diagram, 1+1 Redundancy for 10A output current

Fig. 25-9: Wiring diagram, N+1 Redundancy for 20A output current

Observe the temperature derating requirements of Fig. 25-6 and Fig. 25-7 for N+1 redundancy applications. Note: Use separate mains systems for each power supply whenever it is possible.

## 25.6. SERIES OPERATION

Power supplies of the same type can be connected in series for higher output voltages. It is possible to connect as many units in series as needed, providing the sum of the output voltage does not exceed 150Vdc. Voltages with a potential above 60Vdc are not SELV any more and can be dangerous. Such voltages must be installed with a protection against touching.

Earthing of the output is required when the sum of the output voltage is above 60Vdc.

Avoid return voltage (e.g. from a decelerating motor or battery) which is applied to the output terminals.

Keep an installation clearance of 15mm (left / right) between two power supplies and avoid installing the power supplies on top of each other. Do not use power supplies in series in mounting orientations other than the standard mounting orientation (terminals on the bottom of the unit).

Pay attention that leakage current, EMI, inrush current, harmonics will increase when using multiple power supplies.

## 25.7. CHARGING OF BATTERIES

This redundancy power supply is ideal for charging batteries due to the decoupling circuit built in to the output stage which does not require a fuse or diode between the power supply and the battery.

It can be used to charge sealed lead acid (SLA) or valve regulated lead acid (VRLA) lead batteries when following these instructions:

#### Instructions for charging batteries:

- a) Set output voltage (measured at no load and at the battery end of the cable) very precisely to the end-of-charge voltage.
- b) Ensure that the output current of the power supply is below the allowed charging current of the battery.
- c) Use only matched batteries when putting 12V types in series.
- d) The return current to the power supply (battery discharge current) is typ. 3mA when the power supply is switched off (except in case a blocking diode is utilized).

End-of-charge voltage	27.8V	27.5V	27.15V	26.8V
Battery temperature	10°C	20°C	30°C	40°C

#### 25.8. TWO PHASE OPERATION

The power supply can also be operated on two phases of a three-phase-system. Such a phase-to-phase connection is allowed as long as the supplying voltage is below  $240V^{+10\%}$ .

The maximum allowed voltage between a Phase and the PE must be below 300Vac.







#### 25.9. USE IN A TIGHTLY SEALED ENCLOSURE

When the power supply is installed in a tightly sealed enclosure, the temperature inside the enclosure will be higher than outside. In such situations, the inside temperature defines the ambient temperature for the power supply.

The power supply is placed in the middle of the box, no other heat producing items are inside the box. The temperature sensor inside the box is placed in the middle of the right side of the power supply with a distance of 1cm. The following measurement results can be used as a reference to estimate the temperature rise inside the enclosure.

	Case A	Case B	Case C	Case D
Enclosure size	<b>110</b> x180x165mm Rittal Typ IP66 Box PK 9516 100 plastic	<b>110</b> x180x165mm Rittal Typ IP66 Box PK 9516 100 plastic	<b>180</b> x180x165mm Rittal Typ IP66 Box PK 9519 100 plastic	<b>180</b> x180x165mm Rittal Typ IP66 Box PK 9519 100 plastic
Input voltage	230Vac	230Vac	230Vac	230Vac
Load	24V, 8A; (= <b>80</b> %)	24V, 10A; (= <b>100</b> %)	24V, 8A; ( <b>=80</b> %)	24V, 10A; (= <b>100</b> %)
Temperature inside the box	45.4°C	49°C	42°C	44.4°C
Temperature outside the box	25°C	25°C	25°C	25°C
Temperature rise	20.4K	24K	17K	19.4K



#### **25.10. MOUNTING ORIENTATIONS**

Mounting orientations other than input terminals on the bottom and output on the top require a reduction in continuous output power or a limitation in the maximum allowed ambient temperature.

The amount of reduction influences the lifetime expectancy of the power supply. Therefore, two different derating curves for continuous operation can be found below:

Curve A1 Recommended output current.

Curve A2 Max. allowed output current (results in approximately half the lifetime expectancy of A1).

