

CERTIFICATE OF COMPLIANCE

Certificate Number E198865
Report Reference E198865-20200331
Issue Date 2020-APRIL-07

Issued to: PULS GmbH
Elektrastr 6, 81925 Munchen GERMANY

This certificate confirms that representative samples of POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
See next page for models.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: See next page for Standards for Safety.
Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E198865
Report Reference E198865-20200331
Issue Date 2020-APRIL-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Switch Mode Power Supply

Cat No. PIM36.aab-ww 36W units

aa: 24 Nominal output voltage 24V or 24-28V
b: 1 Protection Class II (no PE), push-in terminals
2 Protection Class II (no PE), push-in terminals
DC-OK signal contact
ww: Blank or numbers or characters -
non-safety critical alterations

The models PIM36.241 and PIM36.242 have a NEC Class 2 output.

Standards for Safety:

UL61010-1 and CAN/CSA C22.2 No. 61010-1-12, Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements

UL61010-2-201 and CAN/CSA-IEC 61010-2-201:18, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 2-201: Particular Requirements for Control Equipment

UL1310, Class 2 Power Units

CSA C22.2 No. 223-15, Power supplies with extra-low-voltage Class 2 outputs



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

