



**BUREAU
VERITAS**

Prüfbescheinigung Test Certificate

Antragsteller: PULS GmbH
Applicant: Elektrastraße 6; 81925 Munich; GERMANY

Produkt: DC-DC Converter (built-in)
Product:

Modell: QTD20.241
Model:

Neendaten: Input: DC 600 V, 1 A
Ratings: Output: DC 24–28 V
20–17,5 A (below +60 °C)
15–13,1 A (at +70 °C)
Derate linearly between +60°C and +70°C

Norm: IEC 61010-1:2010 + AMD1:2016 including IEC 61010-2-201:2017
Standard: EN 61010-1:2010 + A1:2019 + AC:2019 including EN IEC 61010-2-201:2018
EN 61010-1:2010 including EN 61010-2-201:2013+AC:2013

Berichtsnr.: 20TH0202-61010-1_0
Report No.: 20TH0202-61010-2-201_0

Datum: 2020-11-04
Date:



**BUREAU
VERITAS**

BUREAU VERITAS
Consumer Products Services
Germany GmbH
Businesspark A96
86842 Türkheim

Thomas Ruffer
Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17025