

- (12) Issuing body PULS GmbH, Elektrastraße 6, 81925 Munich, Germany
- (13) Remarks Deviating from the product ratings of the QT20.241-C1, which covers an input voltage range from 3AC 380-480V, the railway approval applies only for a reduced input voltage range from 3AC 380-400V.
Due to this fact, the QT20.241-C1 does not bear the railway logo on the product itself.

This is the internet version of the Manufacturer's Declaration which bears no signature but contains the same informations as the signed document. If a copy of a declaration with an actual signature should be needed, please contact your local PULS sales office.

Bernhard Erdl
President

This declaration certifies the compliance with the indicated standards but implies no warranty of properties.
The safety instruction of the product documentation shall be observed.