

Celine1407?

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Power supply

Name and address of the applicant

PULS GmbH
Elektrastr. 6
81925 München
GERMANY

Name and address of the manufacturer

PULS GmbH
Elektrastr. 6
81925 München
GERMANY

Name and address of the factory

PULS INVESTICNI SRO
Prazska 5639
430 01 Chomutov
CZECH REPUBLIC

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

PULS

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

FPT300.246-042-101, FPT300.242-002-101,
FPT300.242-008-102, FPT500.245-034-105,
FPT500.245-018-103, FPT500.241-002-101,
FPT500.241-006-104, FPT500.241-012-103

Additional information (if necessary may also be reported on page 2)

/

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010 + A1:2016
IEC 61010-2-201:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

20TH0250-61010-1_0
20TH0250-61010-2-201_0

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.frSignature: **Gilles LEMONNIER**
Certification Officer

Date: 28/07/2020

ANNEX

References, ratings and main characteristics:**FPT300.246-042-101:**

Input:

3 x 380-480 V; 0,52-0,43 A; 50-60 Hz

Output:

4 x 24-28 Vdc; max. 3,9 - 3,4 A

Total output power:

300 W (at +55 °C)

150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

FPT300.242-002-101, FPT300.242-008-102:

Input:

3 x 380-480 V; 0,52-0,43 A; 50-60 Hz

Output:

24 Vdc; 300 W (below +55 °C)

24 Vdc; 150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

FPT500.245-034-105:

Input:

3 x 380-480 V; 1,1-0,9 A; 50-60 Hz

Output: 4 x 24-28 Vdc; max. 12 A

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +45 °C and +70 °C

FPT500.245-018-103:

Input: 3 x 380-480 V; 1,1-0,9 A; 50-60 Hz

Output:

4 x 24-28 V; max. 9 A

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +45 °C and +70 °C

FPT500.241-002-101, FPT500.241-006-104, FPT500.241-012-103:

Input:

3 x 380-480 V; 1,1-0,9 A; 50-60 Hz

Output:

24-28 Vdc; 600W (below +45 °C)

24-28 Vdc; 500W (below +55 °C)

24-28 Vdc; 350W (at +70 °C)

Derate linearly between +45 °C and +70 °C



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 28/07/2020

Signature: Gilles LEMONNIER
Certification Officer