

IEC**IECEE**

®

™

Ref. Certif. No.

FR_705967/M2**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Power supply
DIN-Rail Power Supply

Name and address of the applicant

PULS GmbH
Elektrastr. 6
81925 München
GERMANY

Name and address of the manufacturer

PULS GmbH
Elektrastr. 6
81925 München
GERMANY

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

PULS

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

PIC480.241C, PIC480.241D, PIC480.241D-C1, PIC480.241D-Q,
PIC480.361D, PIC480.361D-C1, PIC480.481D, PIC480.481D-C1,
PIC480.241D-DC, PIC480.241D-DC-C1

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_705967/M1 dated 19/08/2025. Transistor
V312 & V316 changed from 0,20 to 0,22 Ω
Typo change in critical components Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

ET2025020862A00
19TH0166-62368_0,
19TH0166_62368_0_M1

This CB Test Certificate is issued by the National Certification Body

**LCIE**

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 04/03/2026

Signature

Paola Ferrera
Certification Officer

IEC

TECEE

®

™

Ref. Certif. No.

FR_705967/M2

ANNEX

Name and address of the factories:

PULS ELECTRONICS (SUZHOU) CO. LTD.

No 1 Rui En Lane Xingpu Rd, Sip
Suzhou, Jiangsu, 215021 - CHINA

PULS INVESTICNI SRO

Prazska 5639
430 01 Chomutov
CZECH REPUBLIC

SYRMA SGS Technology LTD

Plot No B27, Phase 2;
Zone B MEPZ-Special Economic Zone; Tambara
Chennai Tamil Nadu 600045
INDIA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 04/03/2026

Signature: Paola Fargira



ANNEX

References, ratings and main characteristics:

PIC480.241C

Input:
200-240 Vac; 2,8 A; 50-60 Hz
Output:
24-28 Vdc; 20-17,1 A (below +55 °C)
24-28 Vdc; 15-12,8 A (at +70 °C)
Derate linearly between +55 °C and +70 °C

PIC480.241D, PIC480.241D-C1, PIC480.241D-Q

Input:
100-240 Vac; 5,4-2,4A; 50-60 Hz
Output:
24-28 Vdc; 20-17,1 A (below +55 °C)
24-28 Vdc; 12,5-10,7 A (at +70 °C)
Derate linearly between +55 °C and +70 °C

PIC480.361D, PIC480.361D-C1

Input:
100-240 Vac; 5,4-2,4 A; 50-60 Hz
Output:
36-42 Vdc; 13,3-11,4 A (below +55 °C)
36-42 Vdc; 8,4-7,1 A (at +70 °C)
Derate linearly between +55 °C and +70 °C

PIC480.481D, PIC480.481D-C1

Input:
100-240 Vac; 5,4-2,4 A; 50-60 Hz
Output:
48-56 Vdc; 10-8,6 A (below +55 °C)
48-56 Vdc; 6,3-5,4 A (at +70 °C)
Derate linearly between +55 °C and +70 °C

PIC480.241D-DC, PIC480.241D-DC-C1

Input:
100-240 Vac; 5,4-2,4 A; 50-60 Hz 110-260 Vdc; 4,9-2,0 A
Output:
24-28 Vdc; 20-17,1 A (below +55 °C)
24-28 Vdc; 12,5-10,7 A (at +70 °C)
Derate linearly between +55 °C and +70 °C



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 04/03/2026

Signature: Paco Ferrera



Certification Officer