INTERNATIONAL ELECTROTECHNICAL COMMISSION (IEC) COMMISSION ELECTROTECHNIQUE INTERNATIONALE (CEI)

IEC SYSTEM FOR CONFORMITY TESTING AND CERTIFICATION OF ELECTRICAL EQUIPMENT (IECEE) CB SCHEME SYSTÈME CEI D'ESSAIS DE CONFORMITÉ ET DE CERTIFICATION DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

100-120/200-240 V AC or 115/230 V AC, 50-60Hz, 2.0/0.9 A, Class I, IP X0

EDITION

3"

Switch Mode Power Supply

Same as applicant

Puls Elektronische Stromversorgungen GmbH Arabellastr. 15 81925 Munich Germany

Puls Elektronische Stromversorgungen GmbH Weltenburgerstr. 6 81677 Munich Germany

SLA3.10X. SLA3.50X and AC1216

PUBLICATION

Output: 30.5 V, 2.8 A

IEC 60950:1999

E137006-A1-CB-2

Product

Name and address of the applicant Nom et adresse du demandeur

Name and address of the manufacturer Nom et advesse du fabricant

Name and address of the factory Nom et adresse de l'astine

Rating and principal characteristics Vuleurs norminales et caractéristiques principales

Trade mark (if any) Mangae de Jabrique (st elle existes

Model/type Ref. Ref. de type

Additional information (if necessary) Information complementative (xl necessalive)

A sample of the product was tested and found to be in conformity with Un échantition de ce produit a été essayé et a été considéré conforme à la

as shown in the Test Report Ref. No, which form part of this certificate comme indiqué dans le Rapport d'essais miniéro de référence qui constitue une partie de ce certificat

This CB Test Certificate is issued by the National Certification Body Ce Certificate d'essal OC est établit par l'Organisme National de Certification

Date 28-08-2002 A Subsidiary of UL International Demko A/S Lyskaer 8, P.O. Box 514 DK-2730, Herley, Denmark Telephone: +45 44856565 Fax: +45 44856500 Steen Lumby Certification Manager Internal Ref.: Holger Laible

Ref. Certif. No.

DK-5470

COVER PAGE FOR TEST REPORT

Test Item Description:	Power Supply, Built-In AC/DC
Model/Type Reference:	SLA3.10X, SLA3.50X and AC1216
Rating(s):	Input: 100-120/200-240 Vac or 115/230 Vac, 2.0/0.9 A, 50-60 Hz
	Output: 30.5 V, 2.8 A
Standards:	IEC60950, Third Edition (1999)
Applicant Name and Address:	PULS ELEKTRONISCHE STROMVERSORGUNGEN GMBH ARABELLASTR 15 81925 MUNICH GERMANY
Factory Location(s):	PULS ELEKTRONISCHE STROMVERSORGUNGEN GMBH WELTENBURGERSTR 6 81677 MUNICH GERMANY
This Report includes the fo	llowing parts, in addition to this cover page:
	 Specific Technical Criteria Clause Verdicts Critical Components Test Results National Differences Enclosures
Test results are valid only f This Test Report can be re Amendments and correctio	

Copyright © 2002 UL International Demko A/S

	TEST REPORT			
IEC 60950				
Safety of i	nformation technology e	quipment		
Report Reference No:	E137006-A1-CB-2			
Compiled by (+ signature)::	Holger Laible	Mills		
Reviewed by (+ signature)::	Manfred Mueller	M. Müller		
Approved by (+ signature)	Steen Lumby			
Date of issue	26-Aug-02			
CB Testing Laboratory	UL International Demko A/S			
Address	Lyskaer 8, 2730, Herlev, Denma	ark		
Testing location/procedure:	CBTL [] SMT []	TMP [x]		
Address:	PULS ELEKTRONISCHE, STR ARABELLASTR 15, 81925 MU			
Applicant's name:				
Address	STROMVERSORGUNGEN			
	GMBH ARABELLASTR 15			
	81925 MUNICH GERMANY			
Test specification:				
Standard:	IEC60950, Third Edition (1999)			
Test procedure	CB Scheme			
Non-standard test method:	N/A			
Test Report Form No	I950F/00-03			
TRF originator:	FIMKO			
Master TRF	dated 00-02			
Copyright © 2001 IEC System for Co (IECEE), Geneva, Switzerland. All rig		tion of Electrical Equipment		
This publication may be reproduced in acknowledged as copyright owner and assume liability for damages resulting to placement and context.	source of the material. IECEE ta	kes no responsibility for and will not		
Test item description:	Power Supply, Built-In AC/DC			
Trade Mark:				
Model/Type reference	SLA3.10X, SLA3.50X and AC12	216		
Manufacturer:	PULS ELEKTRONISCHE STROMVERSORGUNGEN GM ARABELLASTR 15 81925 MUNICH	IBH		

	GERMANY
Rating:	Input: 100-120/200-240 Vac or 115/230 Vac, 2.0/0.9 A, 50-60 Hz
	Output: 30.5 V, 2.8 A

Marking Plate - Refer to Enclosure titled Miscellaneous for copy.

TRF No.: 1950___F

Particulars: test item vs. test requirements	
Equipment mobility	for building-in
Operating condition	continuous
Mains supply tolerance (%)	+6%, -10%
Test for IT power systems	No
IT testing, phase-phase voltage (V)	N/A
Class of equipment	Class I (earthed)
Mass of equipment (kg)	< 1 kg
Protection against ingress of water	IP X0
Possible test case verdicts:	
- test case does not apply to the test object	N / A
- test object does meet the requirement	P(Pass)
- test object does not meet the requirement	F(Fail)
General remarks:	

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by a NCB in accordance with IECEE 02.

The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. Throughout this report a point is used as the decimal separator.

General Product Information:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

Product Description

The unit is a switch mode power supply for DIN Rail mounting. The power supply is considered for building-in and therefore not intended to be connected directly to AC mains supply.

Model Differences

All models are identical, except for changes with affect to appearance only. The character X stands for any number.

Additional Information

N/A

Engineering Consideration		
The product was submitted and tested for use at the manufacturer's recommended ambient temperature (Tmra) of	60°C	
The power supply means are	Permanently connected (field wired)	
The product is intended for use on the following systems:	TN	
Printed wiring board layouts for traces that were investigated as part of the protective earthing path are included in	Enclosure	

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

	5
The following Production-Line tests are conducted for this product:	Earthing Continuity Electric Strength
The end-product Electric Strength Test is to be based upon a maximum working voltage of	342 Vrms, 604 Vpk
The following secondary output circuits are SELV	+/- power output
The following secondary output circuits are at non- hazardous energy levels	+/- power output
The following output terminals were referenced to earth during performance testing	minus

The power supply terminals and/or connectors are	Suitable for field wiring
The maximum investigated branch circuit rating is	15 A
The investigated Pollution Degree is:	2
Proper bonding to the end-product main protective earthing termination is	Required (Terminal block or seperate screw can be used).
An investigation of the bonding terminals as protective earthing terminals has	Been conducted
The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY 2 insulation system with the indicated rating greater than Class A (105°C)	T1 (Class F) and L101 (105°C)
The following end-product enclosures are required	Electrical Fire
The following components require special consideration during end-product Heating tests due to the indicated maximum temperature measurements during component-level testing	Transformer T1: 116.8°C at 60°C ambient

Issue Date:	26-Aug-02	Page 7 of 38	Report Reference #
•			

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

1 GENERAL	Pass
-----------	------

1.5	Components		Pass
1.5.1	Comply with IEC 950 or relevant component standard		Pass
1.5.2	Evaluation and testing of components		Pass
	Dimensions (mm) of mains plug for direct plug-in .:		N/A
	Torque and pull test of mains plug for direct plug-in; torque (Nm); pull (N):		N/A
1.5.3	Thermal controls		N/A
1.5.4	Transformers		Pass
1.5.5	Interconnecting cables		N/A
1.5.6	Capacitors in primary circuits	Line-to-line capacitors are subclass X1 or X2.	Pass
1.5.7	Double or reinforced insulation bridged by components		N/A
1.5.7.1	Bridging capacitors		N/A
1.5.7.2	Bridging resistors		N/A
1.5.7.3	Accessible parts		N/A
1.5.8	Components in equipment for IT power systems		N/A

1.6	Power Interface	Pass
1.6.1	AC power distribution systems	Pass
1.6.2	Input current	Pass
1.6.3	Voltage limit of hand-held equipment	N/A
1.6.4	Neutral conductor	Pass

1.7	Marking and Instructions		Pass
1.7.1	Power rating		N/A
	Rated voltage(s) or voltage range(s) (V)	100-120/200-240 or 115/230	Pass
	Symbol for nature of supply for d.c.		N/A

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

	Rated frequency or frequency range (Hz)	50-60	Pass
	Rated current (A)	2.0/0.9	Pass
	Manufacturer's name/Trademark	PULS	Pass
	Type/model	SLA3.10X, SLA3.50X and AC1216	Pass
	Symbol of Class II		N/A
	Other symbols		N/A
	Certification marks	UL Recognition Mark	Pass
1.7.2	Safety instructions		N/A
1.7.3	Short duty cycles		N/A
1.7.4	Supply voltage adjustment	voltage selector switch visible in unit front and marked with 115/230.	Pass
1.7.5	Power outlets on the equipment		N/A
1.7.6	Fuse identification	Fuse marked with cross reference to service documentation (F101).	Pass
1.7.7	Wiring terminals		Pass
1.7.7.1	Protective earthing and bonding terminals		Pass
1.7.7.2	Terminal for a.c. mains supply conductors	Terminals marked L and N.	Pass
1.7.8	Controls and indicators		Pass
1.7.8.1	Identification, location and marking	voltage selector switch marked with 115/230.	Pass
1.7.8.2	Colours:		N/A
1.7.8.3	Symbols according to IEC 60417		N/A
1.7.8.4	Markings using figures		N/A
1.7.9	Isolation of multiple power sources		N/A
1.7.10	IT power system		N/A
1.7.11	Thermostats and other regulating devices		N/A
1.7.12	Language		-
1.7.13	Durability	Fulfilled by use of UL certified labeling system.	Pass
1.7.14	Removable parts		N/A

Issue Date:	26-Aug-02	Page 9 of 38	Report Reference #
:			

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

1.7.15	Replaceable batteries	N/A
	Language:	-
1.7.16	Operator access with a tool	N/A
1.7.17	Equipment for restricted access locations:	N/A

2	PROTECTION FROM HAZARDS	Pass
---	-------------------------	------

2.1	Protection from electric shock and energy haza	rds	Pass N/A
2.1.1	Protection in OPERATOR access areas	To be determined in the end- product.	
2.1.1.1	Access to energized parts		N/A
	Test by inspection	Unit is intended for building-in.	N/A
	Test with test finger		N/A
	Test with test pin		N/A
	Test with test probe		N/A
2.1.1.2	Battery compartments		N/A
2.1.1.3	Access to ELV wiring		N/A
	Working voltage (V); distance (mm) through insulation		-
2.1.1.4	Access to hazardous voltage circuit wiring		N/A
2.1.1.5	Energy hazards		N/A
2.1.1.6	Manual controls		N/A
2.1.1.7	Discharge of capacitors in the primary circuit	Unit is intended for building-in.	Pass
	Time-constant (s); measured voltage (V)	Unit tested with input voltage of 264 Vac, 50 Hz. After 1.0 sec the voltage dropped to less than 37%. The fuse condition does not affect the result.	-
2.1.2	Protection in service access areas		N/A
2.1.3	Protection in restricted access locations		N/A

IEC 60950
Clause Requirement + Test Result - Remark Verdict

2.2	SELV Circuits		Pass
2.2.1	General requirements		Pass
2.2.2	Voltages under normal conditions (V)	Output voltage is less than 42.4 Vp or 60 V dc and is classified as SELV.	Pass
2.2.3	Voltages under fault conditions (V):	Under fault conditions voltages never exceed 71V peak and 120Vdc and do not exceed 42.4V peak or 60V dc for more than 0.2 sec.	Pass
2.2.3.1	Separation by double or reinforced insulation (method 1)		Pass
2.2.3.2	Separation by earthed screen (method 2)		N/A
2.2.3.3	Protection by earthing of the SELV circuit (method 3)		N/A
2.2.4	Connection of SELV circuits to other circuits:	SELV reliability testing performed. Refer to Table 5.3 for details.	Pass

2.3	TNV Circuits	N/A
2.3.1	Limits	N/A
	Type of TNV circuits	-
2.3.2	Separation from other circuits and from accessible parts	N/A
	Insulation employed	-
2.3.3	Separation from hazardous voltages	N/A
	Insulation employed	-
2.3.4	Connection of TNV circuits to other circuits	N/A
	Insulation employed	-
2.3.5	Test for operating voltages generated externally	N/A

2.4	Limited Current Circuits		N/A
2.4.1	General requirements		N/A
2.4.2	Limit values		N/A

26-Aug-02

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

Report Reference #

Page 11 of 38

	Frequency (Hz):	-
	Measured current (mA):	-
	Measured voltage (V):	-
	Measured capacitance (µF):	-
2.4.3	Connection of limited current circuits to other circuits	N/A

2.5	Limited Power Sources		N/A
	Inherently limited output	Unit output does not meet the requirements of IEC 60950 for LPS, but for NEC Class 2 circuit.	N/A
	Impedance limited output		N/A
	Overcurrent protective device limited output		N/A
	Regulating network limited output under normal operating and single fault condition		N/A
	Regulating network limited output under normal operating conditions and overcurrent protective device limited output under single fault condition		N/A
	Output voltage (V), output current (A), apparent power (VA)		-
	Current rating of overcurrent protective device (A):		-

2.6	Provisions for Earthing and Bonding	Pass
2.6.1	Protective earthing	Pass
2.6.2	Functional earthing	N/A
2.6.3	Protective earthing and protective bonding conductors	Pass
2.6.3.1	Size of protective earthing conductors	N/A
	Rated current (A), cross-sectional area (mm ²), AWG:	-
2.6.3.2	Size of protective bonding conductors	N/A
	Rated current (A), cross-sectional area (mm ²), AWG:	-

	IEC 60950		
Clause	Requirement + Test	Result - Remark	Verdict

2.6.3.3	Rated current (A), type and nominal thread diameter (mm):		N/A
	Resistance (Ohm) of earthing conductors and their terminations, test current (A)	max. 3.2 mOhm tested with 30 A	Pass
2.6.3.4	Colour of insulation		N/A
2.6.4	Terminals		Pass
2.6.4.1	Protective earthing and bonding terminals		Pass
	Rated current (A), type and nominal thread diameter (mm):		-
2.6.4.2	Separation of the protective earthing conductor from protective bonding conductors		N/A
2.6.5	Integrity of protective earthing		Pass
2.6.5.1	Interconnection of equipment		N/A
2.6.5.2	Components in protective earthing conductors and protective bonding conductors		N/A
2.6.5.3	Disconnection of protective earth		N/A
2.6.5.4	Parts that can be removed by an operator		N/A
2.6.5.5	Parts removed during servicing		N/A
2.6.5.6	Corrosion resistance		Pass
2.6.5.7	Screws for protective bonding		Pass
2.6.5.8	Reliance on telecommunication network		N/A

2.7	Overcurrent and Earth Fault Protection in Prima	ry Circuits	Pass
2.7.1	Basic requirements		Pass
	Instructions when protection relies on building installation		N/A
2.7.2	Faults not covered in 5.3		Pass
2.7.3	Short-circuit backup protection		Pass
2.7.4	Number and location of protective devices:	One fuse located in identified side of the line.	Pass
2.7.5	Protection by several devices		N/A
2.7.6	Warning to service personnel		N/A

	IEC 60950		
Clause	Requirement + Test	Result - Remark	Verdict

2.8	Safety Interlocks	N/A
2.8.1	General principles	N/A
2.8.2	Protection requirements	N/A
2.8.3	Inadvertent reactivation	N/A
2.8.4	Fail-safe operation	N/A
2.8.5	Interlocks with moving parts	N/A
2.8.6	Overriding an interlock	N/A
2.8.7	Switches and relays in interlock systems	N/A
2.8.7.1	Contact gaps (mm)	N/A
2.8.7.2	Overload test	N/A
2.8.7.3	Endurance test	N/A
2.8.7.4	Electric strength test (V)	N/A
2.8.8	Mechanical actuators	N/A

2.9	Electrical Insulation	Pass
2.9.1	Properties of insulating materials	Pass
2.9.2	Humidity conditioning	Pass
2.9.3	Requirements for insulation	Pass
2.9.4	Insulation parameters	Pass
2.9.5	Categories of insulation	Pass

2.10	Clearances, Creepage Distances and Distances Through Insulation	Pass
2.10.1	General	Pass
2.10.2	Determination of working voltage	Pass
2.10.3	Clearances	Pass
2.10.3.1	General	Pass
2.10.3.2	Clearances in primary circuit	Pass
2.10.3.3	Clearances in secondary circuits	N/A
2.10.3.4	Measurement of transient levels	N/A

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

2.10.4	Creepage distances		Pass
	CTI tests	Category IIIa and IIIb	-
2.10.5	Solid insulation		Pass
2.10.5.1	Minimum distance through insulation		Pass
2.10.5.2	Thin sheet material		Pass
	Number of layers (pcs)	three	-
	Electric strength test	(see appended table 5.2)	-
2.10.5.3	Printed boards		N/A
	Distance through insulation		N/A
	Electric strength test for thin sheet insulating material		-
	Number of layers (pcs)		N/A
2.10.5.4	Wound components		N/A
	Number of layers (pcs)		N/A
	Two wires in contact inside component; angle between 45° and 90°		N/A
2.10.6	Coated printed boards		N/A
2.10.6.1	General		N/A
2.10.6.2	Sample preparation and preliminary inspection		N/A
2.10.6.3	Thermal cycling		N/A
2.10.6.4	Thermal ageing (°C)		N/A
2.10.6.5	Electric strength test		-
2.10.6.6	Abrasion resistance test		N/A
	Electric strength test		-
2.10.7	Enclosed and sealed parts		N/A
	Temperature T1=T2 + Tmra - Tamb +10K (°C):		N/A
2.10.8	Spacings filled by insulating compound		N/A
	Electric strength test		-
2.10.9	Component external terminations		N/A
2.10.10	Insulation with varying dimensions		N/A

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

3 WIRING, CONNECTIONS AND SUPPLY Pass

3.1	General		Pass
3.1.1	Current rating and overcurrent protection		Pass
3.1.2	Protection against mechanical damage		N/A
3.1.3	Securing of internal wiring		N/A
3.1.4	Insulation of conductors		N/A
3.1.5	Beads and ceramic insulators		N/A
3.1.6	Screws for electrical contact pressure		Pass
3.1.7	Non-metallic materials in electrical connections		N/A
3.1.8	Self-tapping and spaced thread screws	Additional PE screw provided with star washer.	Pass
3.1.9	Termination of conductors		N/A
	10 N pull test		N/A
3.1.10	Sleeving on wiring		N/A

3.2	Connection to A.C. Mains Supplies		N/A
3.2.1	Means of connection	The unit is for building-in. Connection to mains power is to be determined in the end product.	N/A
3.2.2	Multiple supply connections		N/A
3.2.3	Permanently connected equipment		N/A
	Number of conductors, diameter (mm) of cable and conduits:		-
3.2.4	Appliance inlets		N/A
3.2.5	Power supply cords		N/A
	Туре		-
	Rated current (A), cross-sectional area (mm ²),AWG		-
3.2.6	Cord anchorages and strain relief		N/A
	Mass of equipment (kg), pull (N)		-

Issue Date:	
-------------	--

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

	Longitudinal displacement (mm):	-
3.2.7	Protection against mechanical damage	N/A
3.2.8	Cord guards	N/A
	D (mm); test mass (g)	-
	Radius of curvature of cord (mm)	-
3.2.9	Supply wiring space	N/A

3.3	Wiring Terminals for Connection of External Conductors	N/A
3.3.1	Wiring terminals	N/A
3.3.2	Connection of non-detachable power supply cords	N/A
3.3.3	Screw terminals	N/A
3.3.4	Rated current (A), cord/cable type, cross-sectional area (mm ²)	N/A
3.3.5	Rated current (A), type and nominal thread diameter (mm)	N/A
3.3.6	Wiring terminals design	N/A
3.3.7	Grouping of wiring terminals	N/A
3.3.8	Stranded wire	N/A

3.4	Disconnection From the A.C. Mains Supply	N/A
3.4.1	General requirement	N/A
3.4.2	Disconnect devices	N/A
3.4.3	Permanently connected equipment	N/A
3.4.4	Parts which remain energized	N/A
3.4.5	Switches in flexible cords	N/A
3.4.6	Single-phase equipment	N/A
3.4.7	Three-phase equipment	N/A
3.4.8	Switches as disconnect devices	N/A
3.4.9	Plugs as disconnect devices	N/A
3.4.10	Interconnected equipment	N/A

Issue Date:	26-Aug-02	Page 17 of 38	Report Reference #
:			

IEC 60950				
Clause	Requirement + Test		Result - Remark	Verdict

3.4.11	Multiple power sources	N/A

3.5	Interconnection of Equipment		N/A
3.5.1	General requirements		N/A
3.5.2	Types of interconnection circuits		N/A
3.5.3	ELV circuits as interconnection circuits		N/A

I	4	PHYSICAL REQUIREMENTS	Pass
	•		1 400

4.1	Stability	N/A
	Angle of 10°	N/A
	Test: force (N)	N/A

4.2	Mechanical strength	Pass
4.2.1	General	Pass
4.2.2	Steady force test, 10 N	Pass
4.2.3	Steady force test, 30 N	Pass
4.2.4	Steady force test, 250 N	N/A
4.2.5	Impact test	N/A
4.2.6	Drop test	N/A
4.2.7	Stress relief	N/A
4.2.8	Cathode ray tubes	N/A
	Picture tube separately certified	N/A
4.2.9	High pressure lamps	N/A
4.2.10	Wall or ceiling mounted equipment; force (N):	N/A

4.3	Design and Construction	Pass
4.3.1	Edges and corners	Pass
4.3.2	Handles and manual controls; force (N)	N/A

	IEC 60950		
Clause	Requirement + Test	Result - Remark	Verdict

4.3.3	Adjustable controls	N/A
4.3.4	Securing of parts	N/A
4.3.5	Connection of plugs and sockets	N/A
4.3.6	Direct plug-in equipment	N/A
	Torque (Nm)	-
4.3.7	Heating elements in earthed equipment	N/A
4.3.8	Batteries	N/A
4.3.9	Oil and grease	N/A
4.3.10	Dust, powders, liquids and gases	N/A
4.3.11	Containers for liquids or gases	N/A
4.3.12	Flammable liquids	N/A
	Quantity of liquid (I)	N/A
	Flash point (°C)	N/A
4.3.13	Radiation; type of radiation	N/A
	Equipment using lasers	N/A

4.4	Protection Against Hazardous Moving Parts	N/A
4.4.1	General	N/A
4.4.2	Protection in operator access areas	N/A
4.4.3	Protection in restricted access locations	N/A
4.4.4	Protection in service access areas	N/A

4.5	Thermal Requirements	Pass
4.5.1	Temperature rises	Pass
	Normal load condition per Annex L	N/A
4.5.2	Resistance to abnormal heat	Pass

4.6	Openings in Enclosures	N/A
4.6.1	Top and side openings	N/A

5.1

5.1.1

5.1.2

5.1.3

General

Test circuit

Equipment under test (EUT)

Application of measuring instrument

TRF originator:	FIMKO
-----------------	-------

Unit is intended for building-in.

Test circuit of Annex D.1 used.

Pass

Pass

Pass

Pass

Pass

4.7.3.3	Materials for components and other parts outside fire enclosures	N/A
4.7.3.4	Materials for components and other parts inside fire enclosures	Pass
4.7.3.5	Materials for air filter assemblies	N/A
4.7.3.6	Materials used in high-voltage components	N/A
5	ELECTRICAL REQUIREMENTS AND SIMULATED ABNORMAL CONDITIONS	S Pass

Touch current and protective conductor current

Adhesives for constructional purposes Conditioning temperature/time:

4.7	Resistance to Fire	Pass
4.7.1	Reducing the risk of ignition and spread of flame	Pass
4.7.2	Conditions for a fire enclosure	N/A
4.7.2.1	Parts requiring a fire enclosure	Pass
4.7.2.2	Parts not requiring a fire enclosure	N/A
4.7.3	Materials	Pass
4.7.3.1	General	Pass
4.7.3.2	Materials for fire enclosures	N/A
4.7.3.3	Materials for components and other parts outside fire enclosures	N/A
4.7.3.4	Materials for components and other parts inside fire enclosures	Pass
4.7.3.5	Materials for air filter assemblies	N/A
4.7.3.6	Materials used in high-voltage components	N/A

Clause	Requirement + Test	Result - Remark	Verdict
	Dimensions (mm)		-

......

	IEC 60950		
Clause Requi	uirement + Test	Result - Remark	Verdict

Bottoms of fire enclosures

Construction of the bottom

Openings in transportable equipment

Doors or covers in fire enclosures

÷

4.6.2

4.6.3

4.6.4

4.6.5

N/A

-

N/A

N/A

N/A

-

 IEC 60950

 Clause
 Requirement + Test
 Result - Remark
 Verdict

5.1.5	Test procedure		Pass
5.1.6	Test measurements		Pass
	Test voltage (V)	264	-
	Measured current (mA)	0.31 (max.)	-
	Max. allowed current (mA)	3.5	-
5.1.7	Equipment with touch current exceeding 3.5 mA:		N/A
5.1.8	Touch currents to and from telecommunication networks		N/A
5.1.8.1	Limitation of the touch current to a telecommunication network		N/A
	Test voltage (V)		-
	Measured current (mA)		-
	Max. allowed current (mA)		-
5.1.8.2	Summation of touch currents from telecommunication networks		N/A

5.2	Electric Strength		Pass
5.2.1	General		Pass
5.2.2	Test procedure		Pass

5.3	Abnormal Operating and Fault Conditions		Pass
5.3.1	Protection against overload and abnormal operation		Pass
5.3.2	Motors		N/A
5.3.3	Transformers		Pass
5.3.4	Functional insulation	Method B and C.	Pass
5.3.5	Electromechanical components		N/A
5.3.6	Simulation of faults		Pass
5.3.7	Unattended equipment		N/A
5.3.8	Compliance criteria for abnormal operating and fault conditions		Pass

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

6 CONNECTION TO TELECOMMUNICATION NETWORKS N/A

6.1	Protection of telecommunication network service personnel, and users of other equipment connected to the network, from hazards in the equipment		N/A
6.1.1	Protection from hazardous voltages		N/A
6.1.2	Separation of the telecommunication network from ea	arth	N/A
6.1.2.1	Requirements		N/A
	Test voltage (V)		-
	Current in the test circuit(mA):		-
6.1.2.2	Exclusions:		N/A

6.2	Protection of Equipment Users From Overvoltages on Telecommunication Networks		N/A
6.2.1	Separation requirements		N/A
6.2.2	Electric strength test procedure		N/A
6.2.2.1	Impulse test		N/A
6.2.2.2	Steady-state test		N/A
6.2.2.3	Compliance criteria		N/A

6.3	Protection of Telecommunication Wiring System From Overheating	
	Max. output current (A)	-
	Current limiting method	-

А		ANNEX A, TESTS FOR RESISTANCE TO HEAT AND FIRE	N/A	ĺ
---	--	--	-----	---

A.1	Flammability test for fire enclosures of movable equipment having a total mass exceeding 18 kg, and of stationary equipment (see 4.7.3.2)	
A.1.1	Samples, material	-
	Wall thickness (mm)	-
A.1.2	Conditioning of samples; temperature (°C):	N/A

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

A.1.3	Mounting of samples	N/A
A.1.4	Test flame	N/A
A.1.5	Test procedure	N/A
A.1.6	Compliance criteria	N/A
	Sample 1 burning time (s)	-
	Sample 2 burning time (s)	-
	Sample 3 burning time (s)	-

A.2	Flammability test for fire enclosures of movable equipment having a total mass not exceeding 18 kg, and for material and components located inside fire enclosures (see 4.7.3.2 and 4.7.3.4)	
A.2.1	Samples, material	-
	Wall thickness (mm)	-
A.2.6	Compliance criteria	N/A
	Sample 1 burning time (s)	-
	Sample 2 burning time (s)	-
	Sample 3 burning time (s)	-
A.2.7	Alternative test acc. to IEC 60695-2-2, cl. 4, 8	N/A
	Sample 1 burning time (s)	-
	Sample 2 burning time (s)	-
 	Sample 3 burning time (s)	-

A.3	High current arcing ignition test (see 4.7.3.2)	N/A
A.3.1	Samples, material	-
	Wall thickness (mm)	-
A.3.5	Compliance criteria	N/A
	Sample 1 number of arcs to ignition (pcs)	-
	Sample 2 number of arcs to ignition (pcs)	-
	Sample 3 number of arcs to ignition(pcs)	-
	Sample 4 number of arcs to ignition(pcs)	-

IEC 60950				
Clause	Requirement + Test		Result - Remark	Verdict

Sample 5 number of arcs to ignition (pcs)		-
---	--	---

A.4	Hot wire ignition test (see 4.7.3.2)	N/A
A.4.1	Samples, material	-
	Wall thickness (mm)	-
A.4.5	Compliance criteria	N/A
	Sample 1 ignition time (s)	-
	Sample 2 ignition time (s)	-
	Sample 3 ignition time (s)	-
	Sample 4 ignition time (s)	-
	Sample 5 ignition time (s)	-

A.5	Hot flaming oil test (see 4.6.2)	N/A
-----	----------------------------------	-----

A.6	Flammability tests for classifying materials V-0, V-1 or V-2	N/A
A.6.1	Samples, material	-
	Wall thickness (mm)	-
A.6.5	Compliance criteria	N/A
A.6.6	Permitted retest	N/A

A.7	Flammability test for classifying foamed materials HF-1, HF-2 or HFB	N/A
A.7.1	Sample, material	-
	Wall thickness (mm)	-
A.7.4	Compliance criteria	N/A
A.7.5	Compliance criteria, HF-2	N/A
A.7.6	Compliance criteria, HF-1	N/A
A.7.7	Compliance criteria, HBF	N/A
A.7.8	Permitted retest, HF-1 or HF-2	N/A
A.7.9	Permitted retest, HBF	N/A

	IEC 60	0950	
Clause	Requirement + Test	Result - Remark	Verdict

A.8	Flammability test for classifying materials HB	N/A
A.8.1	Samples, material	-
	Sample thickness (mm)	-
A.8.2	Conditioning of samples; temperature (°C)	N/A
A.8.4	Test procedure	N/A
A.8.5	Compliance criteria	N/A
A.8.6	Permitted retest	N/A

A.9	Flammability test for classifying materials 5V	N/A
A.9.1	Samples, material	-
	Sample thickness (mm)	-
A.9.4	Test procedure, test bars	N/A
A.9.5	Test procedure, test plaques	N/A
A.9.6	Compliance criteria	N/A
A.9.7	Permitted retest	N/A

A.10	Stress relief conditioning (see 4.2.7)	N/A
	Temperature (°C)	-

В	ANNEX B, MOTOR TESTS UNDER ABNORMAL CONDITIONS (see 4.7.2.2 and 5.3.2)	
B.1	General requirements	N/A
	Position	-
	Manufacturer	-
	Туре	-
	Rated values	-
B.2	Test conditions	N/A
B.3	Maximum temperatures	N/A

	IE	C 60950		
Clause	Requirement + Test		Result - Remark	Verdict

B.4	Running overload test	N/A
B.5	Locked-rotor overload test	N/A
	Test duration (days)	-
	Electric strength test: test voltage (V)	-
B.6	Running overload test for DC motors in secondary circuits	N/A
B.7	Locked-rotor overload test for DC motors in secondary circuits	N/A
B.7.1	Test procedure	N/A
B.7.2	Alternative test procedure; test time (h)	N/A
B.7.3	Electric strength test	N/A
B.8	Test for motors with capacitors	N/A
B.9	Test for three-phase motors	N/A
B.10	Test for series motors	N/A
	Operating voltage (V)	-

С	ANNEX C, TRANSFORMERS (see 1.5.4 and 5.3.3)		Pass
	Position	T1	-
	Manufacturer	Puls	-
	Туре	E32/16/11	-
	Rated values	N/A	-
	Method of protection	inherently	-
C.1	Overload test	max. 100°C at 24°C ambient	Pass
C.2	Insulation		Pass
	Protection from displacement of windings	margin tape	Pass

	ANNEX G, ALTERNATIVE METHOD FOR DETERMINING MINIMUM CLEARANCES	
	Summary of the procedure for determining minimum clearances	N/A
G.2	Determination of mains transient voltage (V):	N/A

e:	26-Aug-02	Р

IEC 60950			
Clause	Requirement + Test	Result - Remark	Verdict

G.3	Determination of telecommunication network transient voltage (V)	N/A
G.4	Determination of required withstand voltage (V):	N/A
G.5	Measurement of transient levels (V)	N/A
G.6	Determination of minimum clearances	N/A

Н	ANNEX H, IONIZING RADIATION (see 4.3.13)	N/A
	Ionizing radiation	N/A
	Measured radiation (mR/h)	-
	Measured high-voltage (kV)	-
	Measured focus voltage (kV)	-
	CRT markings	-

J	ANNEX J, TABLE OF ELECTROCHEMICAL POTENTIALS (see 2.6.5.6)		Pass
	Metal used:	Aluminum/Zinc	-

K	ANNEX K, THERMAL CONTROLS (see 1.5.3 and 5.3.7)	N/A
K.1	Making and breaking capacity	N/A
K.2	Thermostat reliability; operating voltage (V)	N/A
K.3	Thermostat endurance test; operating voltage (V):	N/A
K.4	Temperature limiter endurance; operating voltage (V)	N/A
K.5	Thermal cut-out reliability	N/A
K.6	Stability of operation	N/A

М	ANNEX M, CRITERIA FOR TELEPHONE RINGING SIGNALS (see 2.3.1)		N/A
M.2	Method A		N/A
M.3	Method B		N/A
M.3.1	Ringing signal		N/A
M.3.1.1	Frequency (f)		-

TRF No.: 1950__F

Issue Date ÷

IEC 60950				
Clause	Requirement + Test	Result - Remark	Verdict	

M.3.1.2	Voltage (V)	-
M.3.1.3	Cadence; time (s), voltage (V)	-
M.3.1.4	Single fault current (mA)	-
M.3.2	Tripping device and monitoring voltage	N/A
M.3.2.1	Conditions for use of a tripping device or a monitoring voltage	N/A
M.3.2.2	Tripping device	N/A
M.3.2.3	Monitoring voltage (V)	N/A

U	ANNEX U, INSULATED WINDING WIRES FOR USE WITHOUT INTERLEAVED INSULATION (see 2.10.5.4)		N/A
	Separate test report		N/A

This is an extract of the CB-Scheme report with the most important information. If a complete copy of the report is required, please contact your PULS sales representative.