

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Power supply Power Supply (built-in)
Name and address of the applicant	PULS GmbH Elektrastr. 6 81925 München Germany
Name and address of the manufacturer	PULS GmbH Elektrastr. 6 81925 München Germany
Name and address of the factory	
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	PIC480.241C PIC480.241D PIC480.361D PIC480.481D
Additional information (if necessary may also be reported on page 2)	/ <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	19TH0166-62368_0

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 05/06/2019

Signature: **Gilles LEMONNIER**
Certification Officer

ANNEX

Name and address of the factories:**PULS ELECTRONICS (SUZHOU) CO. LTD.**

No 1 Rui En Lane Xingpu Rd, Sip
215021 Suzhou
Jiangsu – China

PULS INVESTICNI SRO

Prazska 5639
430 01 Chomutov
Czech Republic

References, ratings and main characteristics:

PIC480.241C	<p>Input: 200-240 Vac; 2,8 A; 50-60 Hz</p> <p>Output: 24-28 Vdc; 20-17,1 A (below +55 °C) 24-28 Vdc; 15-12,8 A (at +70°C)</p> <p>Derate linearly between +55 °C and +70°C</p>
PIC480.241D	<p>Input: 100-240 Vac; 5,4-2,4A; 50-60 Hz</p> <p>Output: 24-28 Vdc; 20-17,1 A (below +55 °C) 24-28 Vdc; 12,5-10,7 A (at +70 °C)</p> <p>Derate linearly between +55 °C and +70 °C</p>
PIC480.361D	<p>Input: 100-240 Vac; 5,4-2,4 A; 50-60 Hz</p> <p>Output: 36-42 Vdc; 13,3-11,4 A (below +55 °C) 36-42 Vdc; 8,4-7,1 A (at +70 °C)</p> <p>Derate linearly between +55 °C and +70 °C</p>
PIC480.481D	<p>Input: 100-240 Vac; 5,4-2,4 A; 50-60 Hz</p> <p>Output: 48-56 Vdc; 10-8,6 A (below +55 °C) 48-56 Vdc; 6,3-5,4 A (at +70 °C)</p> <p>Derate linearly between +55 °C and +70°C</p>



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 05/06/2019

Signature: **Gilles LEMONNIER**
Certification Officer