

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	<b>Power supply</b> Power Supply (built-in)
Name and address of the applicant	<b>PULS GmbH</b> Elektrastr. 6 81925 München - GERMANY
Name and address of the manufacturer	<b>PULS GmbH</b> Elektrastr. 6 81925 München - GERMANY
Name and address of the factory	
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	PIC120.241C, PIC120.242C, PIC120.241D
Additional information (if necessary may also be reported on page 2)	/ <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	19TH0177-62368_0

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 07/06/2019

Signature: **Gilles LEMONNIER**  
Certification Officer

## ANNEX

### Name and address of the factories:

**PULS ELECTRONICS (SUZHOU) CO. LTD.**

No 1 Rui En Lane Xingpu Rd, Sip  
Suzhou, Jiangsu, 215021 – CHINA

**PULS INVESTICNI SRO**

Prazska 5639  
430 01 Chomutov  
- CZECH REPUBLIC

### References, ratings and main characteristics:

**PIC120.241C and PIC120.242C**

## Input:

200-240 Vac; 1,2 A; 50-60 Hz

## Output:

24-28 Vdc; 5,0-4,3 A (below +55 °C)

24-28 Vdc; 3,1-2,7 A (at +70 °C)

Derate linearly between +55 °C and +70 °C

**PIC120.241D**

## Input:

110-120 / 220-240 Vac; 2,4 / 1,2 A; 50-60 Hz

## Output:

24-28 Vdc; 5,0-4,3 A (below +55 °C)

24-28 Vdc; 3,1-2,7 A (at +70 °C)

## Input:

100 / 200 Vac; 2,6 / 1,4 A; 50/60Hz

## Output:

24-28 Vdc; 5,0-4,3 A (below +55 °C)

24-28 Vdc; 2,5-2,1 A (at +70 °C)

Derate linearly between +55 °C and +70 °C



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Gilles LEMONNIER**  
Certification Officer

Date: 07/06/2019