



Ref. Certif. No.

FR_709178/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Power supply

Name and address of the applicant

PULS GmbH
Elektrastr. 6
81925 München
Germany

Name and address of the manufacturer

PULS GmbH
Elektrastr. 6
81925 München
Germany

Name and address of the factory

PULS INVESTICNI SRO
Prazska 5639
430 01 Chomutov
Czech Republic

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

PULS

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

FPT300.24b-ccc-ddd, FPT500.24b-ccc-ddd
(b = 1, 2, 5, 6 or 7; c = 001-999; d = 101-299 or 300-599 or 600-699 for brand labelled units)

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_709178 dated 28/07/2020.
Addition of product references
Update the list of components
Change of the design

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010 + A1:2016
IEC 61010-2-201:2017


As shown in the Test Report Ref. No. which forms part of this Certificate

20TH0250-61010-1_1
20TH0250-61010-2-201_1

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Signature: **Gilles LEMONNIER**
Certification Officer

Date: 17/01/2022

ANNEX

References, ratings and main characteristics:**FPT300.24b-ccc-ddd (b = 1 or 2):****Input:**3 AC 380–480 V ($\pm 15\%$), 0,52–0,43 A, 50–60 Hz**Output:**

1 x 24–28 Vdc, 15–12,9 A or

1 x 24 Vdc, 15 A

Total output power:

300 W (at +55 °C)

150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

Operational temperature range: –25 °C to +70 °C

FPT300.24b-ccc-ddd (b = 5):**Input:**3 AC 380–480 V ($\pm 15\%$), 0,52–0,43 A, 50–60 Hz**Output:****2 x 24–28 Vdc, or****3 x 24–28 Vdc, or****4 x 24–28 Vdc,****max. 12 A**

Total output power:

300 W (at +55 °C)

150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

Operational temperature range: –25 °C to +70 °C

FPT300.24b-ccc-ddd (b = 6):**Input:**3 AC 380–480 V ($\pm 15\%$), 0,52–0,43 A, 50–60 Hz**Output:**

2 x 24–28 Vdc or

3 x 24–28 Vdc or

4 x 24–28 Vdc**max. 3,9–3,4 A**

Total output power:

300 W (at +55 °C)

150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

Operational temperature range: –25 °C to +70 °C

FPT300.24b-ccc-ddd (b = 7):**Input:**3 AC 380–480 V ($\pm 15\%$), 0,52–0,43 A, 50–60 Hz**Output:****A combination of 2 to 4 outputs****24–28 Vdc (NEC Class 2) and****24–28 Vdc (regular) not exceeding 12 A****Total output power:**

Total output power:

300 W (at +55 °C)

150 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

Operational temperature range: –25 °C to +70 °C



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frSignature: **Gilles LEMONNIER**
Certification Officer

Date: 17/01/2022

ANNEX

FPT500.24b-ccc-ddd (b = 1 or 2):**Input:**3 AC 380–480 V ($\pm 15\%$), 1,1–0,9 A, 50–60 Hz**Output:**1 x 24–28 Vdc; **25–21.4 A or****1 x 24 Vdc, 25 A**

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

Operational temperature range: –25 °C to +70 °C

FPT500.24b-ccc-ddd (b = 5):**Input:**

3 AC 380–480 V, 1,1–0,9 A, 50–60 Hz

Output:**2 x 24–28 Vdc, or****3 x 24–28 Vdc, or****4 x 24–28 Vdc,****max. 12 A**

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +45 °C and +70 °C

Operational temperature range: –25 °C to +70 °C

FPT500.24b-ccc-ddd (b = 6):**Input:**3 AC 380–480 V ($\pm 15\%$), 1,1–0,9 A, 50–60 Hz**Output:****4 x 24–28 Vdc****max. 3,9–3,4 A**

Total output power:

400 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +55 °C and +70 °C

Operational temperature range: –25 °C to +70 °C

FPT500.24b-ccc-ddd (b = 7):**Input:**3 AC 380–480 V ($\pm 15\%$), 1,1–0,9 A, 50–60 Hz**Output:****A combination of 2 to 4 outputs****24–28 Vdc (NEC Class 2) and****24–28 Vdc (regular) not exceeding 20 A**

Total output power:

600 W (below +45 °C)

500 W (at +55 °C)

350 W (at +70 °C)

Derate linearly between +45 °C and +70 °C

Operational temperature range: –25 °C to +70 °C



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc

92260 Fontenay-aux-Roses, FRANCE

www.lcie.frSignature: **Gilles LEMOINIER**
Certification Officer

Date: 17/01/2022