



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch Mode Power Supply

Name and address of the applicant

PULS GmbH Elektrastrasse 6, 81925 München, Germany

Name and address of the manufacturer

PULS GmbH Elektrastrasse 6, 81925 München, Germany

Name and address of the factory

See page 2.

Note: When more than one factory, please report on page 2
Ratings and principal characteristics

□ Additional Information on page 2

See page 2.

Trademark / Brand (if any)

PULS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CP20.241-M1

Additional information (if necessary may also be reported on page 2)

The risk management requirements of the standard were not addressed.

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

T223-0250/21 (2022-04-11)

This CB Test Certificate is issued by the National Certification Body



SIQ Ljubljana, Mašera-Spasićeva ulica 10, SI-1000 Ljubljana, Slovenia T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services.

Date: 2022-04-11

Signature: Bojan Pečavar



Name and address of the factory:

1) PULS ELECTRONICS (SUZHOU) CO LTD NO 1 RUI EN LANE XINGPU RD, SIP SUZHOU, JIANGSU 215021, CHINA

2) PULS INVESTICNI S R O PRAZSKA 5639 430 01 CHOMUTOV, CZECH REPUBLIC

Ratings and principal characteristics:

Input:

Input range A: 120-240Vac; 4,3-2,3 A; 50-60 Hz Input range B: 100-240Vac; 4,7-2,1 A; 50-60 Hz

DC input range: 110-150 Vdc; 4,2-3,1 A

Output:

Output @ Input range A:

24-28 Vdc; 20-17,1 A (below +60°C) 24-28 Vdc; 15-12,8 A (at +70°C)

Derate linearly between +60°C and +70°C

Output @ Input range B:

24-28 Vdc; 18-15,4 A (below +60°C) 24-28 Vdc; 13,5-9,6 A (at +70°C)

Derate linearly between +60°C and +70°C

Output @ DC input range:

24-28 Vdc; 18-15,4 A (below +60°C) 24-28 Vdc; 13,5-9,6 A (at +70°C)

Derate linearly between +60°C and +70°C

Additional information (if necessary)

Date: 2022-04-11

Signature: Bojan Pečavar