Ref. Certif. No.

SI-5615

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	DIN Rail Power Supply
Name and address of the applicant Nom et adresse du demandeur	PULS GmbH Elektrastraße 6, D-81925 München, Germany
Name and address of the manufacturer Nom et adresse du fabricant	PULS GmbH Elektrastraße 6, D-81925 München, Germany
Name and address of the factory Nom et adresse de l'usine *Note: When more than one factory, please report on page 2* *Note: Lorsque il y plus d'une usine, veuillez utiliser la 2ème page*	See page 2. ☒ Additional Information on page 2
Ratings and principal characteristics Valeurs nominales et caractéristiques principales	See page 2.
Trademark (if any) Marque de fabrique (si elle existe)	PULS
Type of Manufacturer's Testing Laboratories used Type de programme du laboratoire d'essais constructeur	/
Model / Type Ref. Ref. De type	ML30.xxx-yyy, ML50.xxx-yyy xxx and yyy are non safety relevant modifications related to output voltage or customer specific versions
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2ème page	Unit also complies with EN 60950-1:2006 + A1:2010 + A2:2013 + A11:2009 + A12:2011. For country national deviations refer to test report. ☒ Additional Information on page 2
A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la	IEC 60950-1:2005 (Second Edition) + A1:2009 + A2:2013
As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat	T221-0066/16 issued by laboratory SIQ Testing and Certification GmbH

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

SIQ Ljubljana
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

Date: 2016-09-12

Signature: Bojan Pečavar

Ratings:
Rated Input :

ML50.xxx-yyy (50 W)
AC: 100 – 240 V ac; 1,0 A; 50-60 Hz
DC: 110 – 300 V dc; 0,6 A

ML30.xxx-yyy (≤ 30W)
AC: 100 – 240 V ac; 50-60 Hz; 0,5 A; (25W models); 0,6 A; (30W models)
DC: 110 – 300 V dc; 0,4 A

ML30.xxx-yyy (36W)
AC: 100 – 240 V ac; 0,7 A; 50-60 Hz (36W)
DC: 110 – 300 V dc; 0,4 A

Rated Output:
ML30.xxx-yyy:
5 V d.c. – 48 V d.c.; < 5,5 A; 25 W or 30 W and
+/- 12 - 15 V d.c.; < 2 A; < 36 W

ML50.xxx-yyy:
12 Vd.c. – 58 V d.c.; < 4,2 A; < 50 W

Factory locations:
PULS investicni s.r.o.
Prazska 5639,
CZ-430 01 Chomutov,
Czech Republic

PULS (Suzhou) Co., Ltd.
No. 1 Rui en Lane Xingpu Road,
SIP CN-215021 Suzhou
China

Additional information (if necessary)
Information complémentaire (si nécessaire)

This CB Test Certificate substitutes previously issued CB Test Certificate No. SI-3281, dated 2012-06-06 due to update of the standard.

Date: 2016-09-12 Signature: Bojan Pečavar