



Zertifikat Certificate

Das AS-Interface Produkt
The AS-Interface product

Grundlage des Zertifikates ist die Complete Specification (V 3.0), die aktuelle Prüfordnung und die Zertifizierungsrichtlinie der AS-International Association e.V..

Die Baumusterprüfung des Referenzproduktes wurde durchgeführt im **AS-Interface Prüflabor des Steinbeis Transferzentrum Leipzig**.

Die Baumusterprüfung und die Herstellererklärung wurden für gut befunden.

Die Verantwortung für das Produkt verbleibt beim Hersteller.

The Certificate is based on the Complete Specification (V 3.0), the actual test requirements and the certification guideline of AS-International Association e.V..

The type test of the reference product was performed by the AS-Interface test laboratory at the Steinbeis Transferzentrum Leipzig.

The type test and the manufacturer declaration have been approved to be good.

The manufacturer is responsible for his product.

**AS-Interface DC/DC Wandler; Eingang DC 24V;
Ausgang 30,6V und 4A**

**AS-Interface DC/DC Converter; Input: DC 24V;
Output: 30.6V and 4A**

der Firma
of the company

PULS GmbH

in/at D-81925 Munich

wurde gemäß der Complete Specification (V 3.0)
entwickelt.

has been developed according to the Complete
Specification (V 3.0).


Das Produkt hat die Bezeichnung
The Product has the designation

SLAD4.100

Dies Produkt darf mit dem Zertifizierungslogo und der Nummer der Zertifizierungs-urkunde (ZU-Nr.) gekennzeichnet werden.
This product may be marked with the certification Logo and the Number of the certification document (ZU-No.).



Gelnhausen, Germany, 15.November 2007


Zertifizierungsstelle – certification office
AS-International Association

Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: 1 of 11 pages	Test of PSU Type: SLDA4.100

Test Report on an AS-Interface Power Supply

Tested Power Supply: DC/DC-Converter 24Vdc to 30,5Vasi/4A

Test Report: PSU 66 / 07

Kind of test: basic test

Date: 04. 10. 2007

Manufacturer/Customer: PULS GmbH

This report contains:

11 pages test sheets (altogether)

9 pages measuring papers and attachments


the test order form AS-Interface Power Supply by the customer

the manufacturers declaration by the customer

a set of documents provided by the customer (data sheets, description)

The test results of this report refer to the tested samples only.

This report shall not be copied in total or in parts without the written consent of the test laboratory.

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------

Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: 2 of 11 pages	Test of PSU Type: SLDA4.100

Test laboratory: Steinbeis Transferzentrum "AIE"

Address: Wächterstraße 13
D-04107 Leipzig

Customer: PULS GmbH

Address: Arabellastraße 15
D-81925 München

Manufacturer: PULS GmbH

Address: Arabellastraße 15
D-81925 München

Test object: DC/DC-Converter 24Vdc to 30,5Vasi/4A

Type: SLDA4.100


Code of samples: PS 1


The tests were conducted according to the following documents:

- EN 50295:1999: Low-voltage switchgear and controlgear; Controller-device interface systems; Actuator Sensor Interface (AS-i)
- Actuator-Sensor-Interface: Complete Spec., Version: 3.0, Rev. 1 of: 04. October 2006 inclusive Annex A, Annex B (Slave-/Master-Profiles) and Annex C (Test Requirements)
- Additional documents:


Date: 04. 10. 2007

Signature:


i.v. Dr. sc. W. Kutsch
Authorized person


Signature: 	Authorized person: Telschow
-------------------------------------------------------------------------------------------------------	---------------------------------------

Standard and clause	Kind of tests and requirements Sample: <i>PS1</i>	Test values Results
5.3.4, 8.2.4	<p>IMPEDANCE TEST CIRCUIT</p> <p>The test instruction allows to test the impedance of an AS-Interface power supply "in operative state" under laboratory conditions on the basis of a compensation method (bridge circuit). It is not the absolute impedance which is determined, but only the observation or exceeding of the required tolerance limit.</p> <p>TEST PROCEDURE</p> <p>Test values:</p> <p style="text-align: right;">PS1: U1dc = <i>30,5</i> V <i>I</i>_{E1}: I_{E1} = <i>4</i> A PS2: U2dc = <i>-</i> V <i>I</i>_{E2}: I_{E2} = <i>-</i> A <i>I</i>_{max}: I_{max} = <i>-</i> A</p> <p>EVALUATION OF TEST RESULTS</p> <p>Current I (PS2) = 0.1A (fixed) Frequency = 50kHz; Current I (PS1): 0.1A Yes [<input checked="" type="checkbox"/>] No [] <i>I</i>_{E1}: I_{E1} Yes [<input checked="" type="checkbox"/>] No [] Frequency = 300kHz; Current I (PS1): 0.1A Yes [<input checked="" type="checkbox"/>] No [] <i>I</i>_{E1}: I_{E1} Yes [<input checked="" type="checkbox"/>] No []</p> <p>Current I (PS 2) = I_{E2} (fixed) Frequency = 50kHz; Current I (PS1): 0.1A Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E1}: I_{E1} Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] Frequency = 300kHz; Current I (PS1): 0.1A Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E1}: I_{E1} Yes [<input type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Current I (PS1) = 0.1A (fixed) Frequency = 50kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E2}: I_{E2} Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] Frequency = 300kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E2}: I_{E2} Yes [<input type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Current I (PS1) = I_{E1} (fixed) Frequency = 50kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E2}: I_{E2} Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] Frequency = 300kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E2}: I_{E2} Yes [<input type="checkbox"/>] No [<input type="checkbox"/>]</p> <p style="text-align: right;"><i>Impedance test passed:</i> YES [<input checked="" type="checkbox"/>] NO []</p>	<p>Bridge alignment possible?</p>

Signature: 


Authorized person:
Telschow

Standard and clause	Kind of tests and requirements Sample: <i>PS1</i>	Test values Results
5.3.4 8.2.4	<p>SYMMETRY TEST CIRCUIT</p> <p>The test instruction allows to test the symmetry of an AS-Interface power supply "in operative state" under laboratory conditions on the basis of a compensation method (bridge circuit). It is checked whether the required tolerance limit is observed or exceeded.</p> <p>TEST PROCEDURE</p> <p>Test values:</p> <p>PS1: U1dc = <i>30.5</i> V <i>I</i>_{E1}: <i>I</i>_{E1} = <i>4.0</i> A PS2: U2dc = <i>✓</i> V <i>I</i>_{E2}: <i>I</i>_{E2} = <i>✓</i> A <i>I</i>_{max}: <i>I</i>_{max} = <i>✓</i> A</p> <p>EVALUATION OF TEST RESULTS</p> <p>Current I (PS2) = 0.1A (fixed)</p> <p>Frequency = 50kHz; Current I (PS1): 0.1A Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E1}: Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Frequency = 160kHz; Current I (PS1): 0.1A Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E1}: Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Frequency = 300kHz; Current I (PS1): 0.1A Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>] <i>I</i>_{E1}: Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Current I (PS 2) = <i>I</i>_{E2} (fixed)</p> <p>Frequency = 50kHz; Current I (PS1): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E1}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Frequency = 160kHz; Current I (PS1): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E1}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Frequency = 300kHz; Current I (PS1): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E1}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Current I (PS1) = 0.1A (fixed)</p> <p>Frequency = 50kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E2}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Frequency = 160kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E2}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Frequency = 300kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E2}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Current I (PS1) = <i>I</i>_{E1} (fixed)</p> <p>Frequency = 50kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E2}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Frequency = 160kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E2}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>Frequency = 300kHz; Current I (PS2): 0.1A Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>] <i>I</i>_{E2}: Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p style="text-align: right;">Symmetry test passed: YES [<input checked="" type="checkbox"/>] NO [<input type="checkbox"/>]</p>	<p>Bridge alignment possible?</p>

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------


Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: 5 of 11 pages	Test of PSU Type: SLDA4.100

Standard and clause	Kind of tests and requirements Sample: <i>PS1</i>	Test values Results
5.3.1	<p>NOISE EMISSION TEST CIRCUIT The test instruction allows to verify the noise emission of an AS-Interface power supply in stationary state in the specified nominal-load range of 0.1A ... I_E under laboratory conditions. It is checked whether the required tolerance limit is observed.</p> <p>TEST PROCEDURE Test values:</p> <p style="text-align: right;">PS1: U1dc =V I_{E1}: I_{E1} =A PS2: U2dc =V I_{E2}: I_{E2} =A I_{max}: I_{max} =A</p> <p>EVALUATION OF TEST RESULTS</p> <p>PS1: Current I (PS2) = 0.1A Frequency range: 0...10kHz; (max. V_{pp} = 300mV_{pp}) Noise: V_{pp} mV_{pp} Frequency range: 10...500kHz; (max. V_{pp} = 50mV_{pp}) Noise: V_{pp} mV_{pp} Current I (PS2) = I_{E2} Frequency range: 0...10kHz; (max. V_{pp} = 300mV_{pp}) Noise: V_{pp} mV_{pp} Frequency range: 10...500kHz; (max. V_{pp} = 50mV_{pp}) Noise: V_{pp} mV_{pp} PS1: Test passed: Yes [] No []</p> <p>PS2: Current I (PS1) = 0.1A Frequency range: 0...10kHz; (max. V_{pp} = 300mV_{pp}) Noise: V_{pp} mV_{pp} Frequency range: 10...500kHz; (max. V_{pp} = 50mV_{pp}) Noise: V_{pp} mV_{pp}</p> <p>Current I (PS1) = I_{E1} Frequency range: 0...10kHz; (max. V_{pp} = 300mV_{pp}) Noise: V_{pp} mV_{pp} Frequency range: 10...500kHz; (max. V_{pp} = 50mV_{pp}) Noise: V_{pp} mV_{pp} PS2: Test passed: Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p style="text-align: right;"><i>Noise emission test passed:</i> YES [<input checked="" type="checkbox"/>] NO [<input type="checkbox"/>]</p>	<p>U1dc = <i>305</i> V I_{E1} = <i>40</i> A U2dc = V I_{E2} = A I_{max} = A</p> <p>V_{pp} <i>15</i> mV_{pp} V_{pp} <i>35</i> mV_{pp}</p> <p>V_{pp} mV_{pp} V_{pp} mV_{pp}</p> <p>V_{pp} mV_{pp} V_{pp} mV_{pp}</p> <p>PS1: Test passed: Yes [] No []</p> <p>V_{pp} mV_{pp} V_{pp} mV_{pp}</p> <p>V_{pp} mV_{pp} V_{pp} mV_{pp}</p> <p>PS2: Test passed: Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>YES [<input checked="" type="checkbox"/>] NO [<input type="checkbox"/>]</p>

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------

Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: 6 of 11 pages	Test of PSU Type: SLDA4.100

Standard and clause	Kind of tests and requirements Sample: <i>PS1</i>	Test values Results
5.3.3, 8.2.2	<p>START UP BEHAVIOUR TEST CIRCUIT</p> <p>The test instruction allows to verify the start up behaviour (time of readiness for service) of an AS-Interface power supply under maximum load of I_E under laboratory conditions. It is checked whether the required tolerance limits are observed.</p> <p>TEST PROCEDURE</p> <p>Test values: _____ PS1: U1dc = <i>30.5</i> V I_{E1}: _____ I_{E1} = <i>40</i> A PS2: U2dc = _____ V I_{E2}: _____ I_{E2} = _____ A I_{max}: _____ I_{max} = _____ A</p> <p>EVALUATION OF TEST RESULTS</p> <p>PS1: Current I (PS2) = 0.1A Voltage: 5.0...26.5V; (max. t = 2s) Timing: t = <i>360</i> ms Voltage: 21.5...29.5V; (max. t = 1s) Timing: t = <i>180</i> ms Current I (PS2) = I_{E2} Voltage: 5.0...26.5V; (max. t = 2s) Timing: t = _____ ms Voltage: 21.5...29.5V; (max. t = 1s) Timing: t = _____ ms PS1: Test passed: Yes [<input checked="" type="checkbox"/>] No []</p> <p>PS2: Current I (PS1) = 0.1A Voltage: 5.0...26.5V; (max. t = 2s) Timing: t = _____ ms Voltage: 21.5...29.5V; (max. t = 1s) Timing: t = _____ ms Current I (PS1) = I_{E1} Voltage: 5.0...26.5V; (max. t = 2s) Timing: t = _____ ms Voltage: 21.5...29.5V; (max. t = 1s) Timing: t = _____ ms PS2: Test passed: Yes [<input checked="" type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p> <p>AS-Interface voltage waveforms continuous? Yes [<input checked="" type="checkbox"/>] No [] Annex: Oscillogram plots (number: <i>1</i>.....) Yes [<input checked="" type="checkbox"/>] No []</p> <p style="text-align: right;">Start up behaviour test passed: YES [<input checked="" type="checkbox"/>] NO []</p>	

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------

Start up behaviour


report no: PSU 66 / 023391, FLUKE LITS

page 7 of 11


ch1

Subs

Typ: SLD44.100




Standard and clause	Kind of tests and requirements Sample: <i>PS1</i>	Test values Results
8.2.1, EN61000- 4-4	<p>FAST TRANSIENT IMMUNITY (BURST) TEST CIRCUIT</p> <p>The test is performed with quick, transient disturbances in the form of pulse groups (burst). The disturbances are capacity-coupled secondarily via a coupling clamp on the AS-Interface line, or via primary coupling filters.</p> <p>TEST PROCEDURE</p> <p>Test values:</p> <p style="text-align: right;">PS1: U1dc = 305 V I_{E1}: I_{E1} = 4.0 A PS2: U2dc = / V I_{E2}: I_{E2} = / A I_{max}: I_{max} = / A</p> <p>EVALUATION OF TEST RESULTS</p> <p>1kV:</p> <p>PS1:</p> <p>Output current of the power supply not being tested (PS2): I_{E2} = 0.1A</p> <p>BURST coupling: primary Positive polarity: N_{ref.}: 0 errors N_{meas}: 0 errors Negative polarity: N_{ref.}: 0 errors N_{meas}: 0 errors</p> <p>BURST coupling: secondary Positive polarity: N_{ref.}: 0 errors N_{meas}: 0 errors Negative polarity: N_{ref.}: 0 errors N_{meas}: 0 errors</p> <p>I_{E2} = max. I</p> <p>BURST coupling: primary Positive polarity: N_{ref.}: / errors N_{meas}: / errors Negative polarity: N_{ref.}: / errors N_{meas}: / errors</p> <p>BURST coupling: secondary Positive polarity: N_{ref.}: / errors N_{meas}: / errors Negative polarity: N_{ref.}: / errors N_{meas}: / errors</p> <p>Fast transient immunity PS1 (1 kV) test passed: Yes <input checked="" type="checkbox"/> No []</p> <p>PS2:</p> <p>Output current of the power supply not being tested (PS1): I_{E1} = 0.1A</p> <p>BURST coupling: primary Positive polarity: N_{ref.}: / errors N_{meas}: / errors Negative polarity: N_{ref.}: / errors N_{meas}: / errors</p> <p>BURST coupling: secondary Positive polarity: N_{ref.}: / errors N_{meas}: / errors Negative polarity: N_{ref.}: / errors N_{meas}: / errors</p> <p>I_{E1} = max. I</p> <p>BURST coupling: primary Positive polarity: N_{ref.}: / errors N_{meas}: / errors Negative polarity: N_{ref.}: / errors N_{meas}: / errors</p> <p>BURST coupling: secondary Positive polarity: N_{ref.}: / errors N_{meas}: / errors Negative polarity: N_{ref.}: / errors N_{meas}: / errors</p> <p>Fast transient immunity PS2 (1kV) test passed: Yes <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/></p>	

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------


Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: 9 of 11 pages	Test of PSU Type: SLDA4.100

Standard and clause	Kind of tests and requirements Sample: <i>PS1</i>	Test values Results
8.2.1, EN61000- 4-4	EVALUATION OF TEST RESULTS 2kV: PS1: $I_{E1} = 0.1A$ $I_{E2} = 0.1A$ (Output current of the power supply (PS2) not being tested)	
	Test 1: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: secondary Positive polarity: Negative polarity:	correct? Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No []
	Test 2: $U_{ASI} < 31.6V$ with earthing, BURST coupling: secondary Positive polarity: Power supply operational? Negative polarity: Power supply operational?	Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No []
	Test 3: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: primary Positive polarity: Power supply operational? Negative polarity: Power supply operational?	Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No [] Yes <input checked="" type="checkbox"/> No []
	$I_{E2} = \text{max. Output current (PS2):}$ Test 1: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: secondary Positive polarity: Negative polarity:	Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>]
	Test 2: $U_{ASI} < 31.6V$ with earthing, BURST coupling: secondary Positive polarity: Power supply operational? Negative polarity: Power supply operational?	Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>]
	Test 3: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: primary Positive polarity: Power supply operational? Negative polarity: Power supply operational?	Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>] Yes <input type="checkbox"/> No [<input type="checkbox"/>]

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------


Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: 10 of 11 pages	Test of PSU Type: SLDA4.100

Standard and clause	Kind of tests and requirements Sample: PS1	Test values Results
8.2.1, EN61000- 4-4	EVALUATION OF TEST RESULTS 2kV: PS1: $I_{E1} = \text{max. Output current (PS1)}$ $I_{E2} = 0.1A$ (Output current of the power supply (PS2) not being tested) Test 1: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: secondary Positive polarity: Negative polarity: Test 2: $U_{ASI} < 31.6V$ with earthing, BURST coupling: secondary Positive polarity: Power supply operational? Negative polarity: Power supply operational? Test 3: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: primary Positive polarity: Power supply operational? Negative polarity: Power supply operational? $I_{E2} = \text{max. Output current (PS2):}$ Test 1: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: secondary Positive polarity: Negative polarity: Test 2: $U_{ASI} < 31.6V$ with earthing, BURST coupling: secondary Positive polarity: Power supply operational? Negative polarity: Power supply operational? Test 3: $U_{ASI} = 29.5V \dots 31.6V$ BURST coupling: primary Positive polarity: Power supply operational? Negative polarity: Power supply operational? Fast transient immunity PS1 (2kV) test passed:	correct? Yes [<input checked="" type="checkbox"/>] No [] Yes [<input checked="" type="checkbox"/>] No [] Yes [<input checked="" type="checkbox"/>] No [] Yes [<input checked="" type="checkbox"/>] No [] Yes [<input checked="" type="checkbox"/>] No [] Yes [<input checked="" type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] Yes [<input type="checkbox"/>] No [] YES [<input checked="" type="checkbox"/>] NO []

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------

Report-No.: PSU 66 / 07	Test laboratory: Steinbeis Transferzentrum Leipzig
page: <u>M</u> of <u>M</u> pages	Test of PSU Type: SLDA4.100

Standard and clause	Kind of tests and requirements Sample: <u>PSA</u>	Test values Results
5.3, 8.2	<p>INTEROPERABILITY IN THE REFERENCE NETWORK TEST CIRCUIT</p> <p>The test instruction allows to test the function of an AS-Interface power supply on the AS-Interface reference network under laboratory conditions. The purpose of this test is to prove the error-free communication between the master and all 31 slaves.</p> <p>TEST PROCEDURE</p> <p>Test values:</p> <p style="text-align: right;">PS1: U1dc = <u>30.5</u> V I_{E1}: I_{E1} = <u>4.0</u> A PS2: U2dc = <u>-</u> V I_{E2}: I_{E2} = <u>-</u> A I_{max}: I_{max} = <u>-</u> A</p> <p>EVALUATION OF TEST RESULTS</p> <p>Measuring time: t = <u>2</u> min</p> <p>PS1:</p> <p>Number of errors: <u>0</u> errors < 1 errors/min.: Yes [<input checked="" type="checkbox"/>] No [] PS1 Test passed: Yes [<input checked="" type="checkbox"/>] No []</p> <p>PS2:</p> <p>Number of errors: <u>1</u> errors < 1 errors/min.: Yes [] No [<input checked="" type="checkbox"/>] PS2 Test passed: Yes [<input checked="" type="checkbox"/>] No []</p> <p style="text-align: right;"><i>Interoperability in the reference network test passed:</i> YES [<input checked="" type="checkbox"/>] NO []</p>	

Signature: 	Authorized person: Telschow
------------------------------------------------------------------------------------------------	--------------------------------

Recommendations to the Certification Office:

Concerning test report no.: PSW 66107

Test Result:

Comments / conditions:

Certification: Yes / ~~No~~


Cancellation: Yes / ~~No~~

Withdrawal: Yes / ~~No~~

Conditions / restrictions:

Extensions (para. 2.4 ZRL)

Date of issue: 04. 10. 2007

Signature: 
i.v. Prof. Dr. sc. W. Kriesel
Authorized person