

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Protection module with integrated electronic fuses
Name and address of the applicant	PULS GMBH ELEKTRASTR 6 MUNCHEN 81925 GERMANY
Name and address of the manufacturer	PULS GMBH ELEKTRASTR 6 MUNCHEN 81925 GERMANY
Name and address of the factory	See Page 3 <input checked="" type="checkbox"/> Additional Information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See Page 2 <input checked="" type="checkbox"/> Additional Information on page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	PISA-B-812-B1, PISA-B-812-B4, PISA-B-8CL2-B1, PISA-B-8CL2-B4 PISA-B-812-B1-70, PISA-B-8CL2-B1-72, PISA-B-810.000. <input type="checkbox"/> Additional Information on page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN 61010-1:2010/A1:2019; EN IEC 61010-2-201:2018. National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016, IEC 61010-2-201:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	E198865-4789663277-CB issued on 2021-03-18

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2021-03-26

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

**DK-111289-UL**

**Model and Ratings:**

Model No. PISA-B-812-B1, PISA-B-812-B4, PISA-B-812-B1-70, PISA-B-800.000

**Input:**

DC 24, 40A

**Output:**

Channel 1-2: DC 24V, 1-12A adjustable

Channel 3-8: DC 24V, 1-10A adjustable

Channel 1-2 optimized for capacitive loads

Operational temp. range: -25°C to +70°C

Model No. PISA-B-8CL2-B1, PISA-B-8CL2-B4, PISA-B-8CL2-B1-72

**Input:**

DC 24, 30A (40A with extension modules)

**Output:**

Channel 1-8: DC 24V, max. 100VA

Channel 1-2 optimized for capacitive loads

Operational temp. range: -25°C to +70°C

**Additional information (if necessary)**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2021-03-26

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

**DK-111289-UL**

**Factories:**

PULS ELECTRONICS (SUZHOU) CO LTD  
NO 1 RUI EN LANE XINGPU RD, SIP  
SUZHOU  
JIANGSU 215021 CHINA

PULS INVESTICNI S R O  
PRAZSKA 5639  
430 01 CHOMUTOV CZECH REPUBLIC

**Additional information (if necessary)**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2021-03-26

Signature:

Jan-Erik Storgaard