

CERTIFICATE OF COMPLIANCE

Certificate Number E327416
Report Reference E327416-20211209
Date 2021-December-13

Issued to: PULS GmbH
Elektrastr 6
Munchen 81925 DE

**This is to certify that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page for Standard(s)

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E327416
Report Reference E327416-20211209
Date 2021-December-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL, CNL – Open Type - Industrial Control Equipment for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

Dual Redundancy Module, Cat. Nos. MLY02.100
YR40.242, YR40.245
YR80.242, YR40.482
YR20.242, YR20.246, PIRD20.241

Standard(s)

UL 121201 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 213 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

